



Pacific Northwest
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

Impacts of Model Building Energy Codes

October 2016

RA Athalye
D Sivaraman
DB Elliott

B Liu
R Bartlett



Prepared for the U.S. Department of Energy
under Contract DE-AC05-76RL01830

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes **any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights.** Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST NATIONAL LABORATORY
operated by
BATTELLE
for the
UNITED STATES DEPARTMENT OF ENERGY
under Contract DE-AC05-76RL01830

Printed in the United States of America

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information,
P.O. Box 62, Oak Ridge, TN 37831-0062;
ph: (865) 576-8401
fax: (865) 576-5728
email: reports@adonis.osti.gov

Available to the public from the National Technical Information Service
5301 Shawnee Rd., Alexandria, VA 22312
ph: (800) 553-NTIS (6847)
email: orders@ntis.gov <<http://www.ntis.gov/about/form.aspx>>
Online ordering: <http://www.ntis.gov>



This document was printed on recycled paper.

(8/2010)

Impacts of Model Building Energy Codes

RA Athalye
D Sivaraman
DB Elliott

B Liu
R Bartlett

October 2016

Prepared for
the U.S. Department of Energy
under Contract DE-AC05-76RL01830

Pacific Northwest National Laboratory
Richland, Washington 99352

Executive Summary

The U.S. Department of Energy (DOE) Building Energy Codes Program (BECP) periodically evaluates national and state-level impacts associated with energy codes in residential and commercial buildings. Pacific Northwest National Laboratory (PNNL), funded by DOE, conducted an assessment of the prospective impacts of national model building energy codes from 2010 through 2040. A previous PNNL study evaluated the impact of the Building Energy Codes Program¹; this study looked more broadly at overall code impacts. This report describes the methodology used for the assessment and presents the impacts in terms of energy savings, consumer cost savings, and reduced CO₂ emissions at the state level and at aggregated levels. This analysis does not represent all potential savings from energy codes in the U.S. because it excludes several states which have codes which are fundamentally different from the national model energy codes or which do not have state-wide codes.

Energy codes follow a three-phase cycle that starts with the development of a new model code, proceeds with the adoption of the new code by states and local jurisdictions, and finishes when buildings comply with the code. The development of new model code editions creates the potential for increased energy savings. After a new model code is adopted, potential savings are realized in the field when new buildings (or additions and alterations) are constructed to comply with the new code. Delayed adoption of a model code and incomplete compliance with the code’s requirements erode potential savings. The contributions of all three phases are crucial to the overall impact of codes, and are considered in this assessment.

Figure ES.1 schematically describes the analysis framework. Energy savings are expressed in terms of energy use intensity (EUI) in the figure.




Figure ES.1. Codes Impact Analysis Framework

¹ Building Energy Codes Program: National Benefits Assessment, 1992-2040. Available at: https://www.energycodes.gov/sites/default/files/documents/BenefitsReport_Final_March20142.pdf

Determine Code Effective Date. The years in which each state adopted various code editions must be known to calculate savings. PNNL collected data on the years in which various code editions were adopted by each state and verified the accuracy of the adoption data with the Regional Energy Efficiency Organizations (REEOs) across the country. In states with no state-wide code but with significant adoption and code activities in local jurisdictions (Arizona, Colorado, and Wyoming), the code effective in populous jurisdictions is used as a surrogate for the state-wide code.

Historical adoption data since 1992 is used to project the rate at which each state will adopt codes in the future, i.e., from 2017 through 2040. States are classified as timely, medium slow, or very slow adopters of energy codes, which then determines how fast a state will adopt a new code in the future. The following states are excluded from the analysis because they do not have a state-wide code and energy codes are not enforced by jurisdictions within the state: Alaska, Hawaii, Kansas, Missouri, Mississippi (excluded only from residential calculations), North Dakota, and South Dakota.

Calculate Potential EUI Savings. Once the adoption years of various code editions are known, it is possible to calculate savings from one code to the next. All code-to-code savings are counted towards the impact of energy codes; savings from beyond-code programs that may be active in the states are not counted towards energy codes. Code savings are calculated by first determining the EUI of each code edition. DOE's Determination analyses of the last four cycles of commercial and residential codes, conducted by PNNL², are used to develop these EUIs. Savings resulting from improvements in equipment efficiency due to federally mandated requirements are not included in this analysis. EUIs of future code editions are based on projected improvements in various building technologies (envelope, heating, ventilating, air conditioning, lighting, and water heating). California, Oregon, and Washington are excluded from the assessment because their energy codes are significantly different from the model codes for which EUIs are developed using the Determination analyses.

De-Rate Potential EUI Savings. To capture the impact of code requirements not being met, potential savings from a new code are de-rated by a realization rate, defined as the fraction of total potential energy savings achieved in the field. Data from DOE's residential field study³ are used to determine residential code realization rates. The savings realization rate in the first year after a residential code is adopted is 80%, increasing each year and ending at 100% after 10 years. For commercial codes, a literature review found that past compliance studies were insufficient to make statistically valid judgements on savings realization rates for entire states. Past studies also did not report the fraction of potential energy savings realized in the field. In the absence of defensible data, a conservative realization rate of 50% was chosen for the first year after a code is adopted, increasing each year and ending at 80% after 10 years.

Incremental Savings. Having calculated savings based on individual code EUIs, the adoption scenarios in each state, and realization rates, the EUI savings are multiplied by new floor space to calculate the incremental savings for each state. New floor space estimates for commercial and residential buildings developed in a previous analysis⁴ were updated using new data from Annual Energy Outlook

² Determination analyses: <https://www.energycodes.gov/determinations>.

³ DOE residential field study: <https://www.energycodes.gov/compliance/residential-energy-code-field-study>.

⁴ Building Energy Codes Program: National Benefits Assessment, 1992-2040. Available at: www.energycodes.gov.

2015.⁵ New floor space added each year includes new construction, additions, and, for commercial buildings only, alterations.

Annual and Cumulative Savings. Projected impacts are reported in terms of annual savings in a given year, as well as cumulative savings for different periods. The terms annual and cumulative are described in greater detail in section 2.2.

Table ES.1 summarizes the impact of energy codes beginning in 2010 and ending in 2040 for all states included in the analysis. The results include savings from electricity, natural gas, and fuel oil (residential only) and are reported separately for residential and commercial codes. The cumulative primary energy savings from 2010-2040 are 12.82 quads. In terms of financial benefits to consumers from reduced utility bills, energy codes could save \$126 billion dollars from 2010 to 2040. This equates to a CO₂ reduction of 841 million metric tons (MMT). These savings are approximately equal to the greenhouse gases emitted by 177 million passenger vehicles driven for one year or the CO₂ emissions from 245 coal power plants for one year⁶.

Table ES.1. Summary of Impact of Energy Codes

Sector	Site Energy Savings (Quads)	Primary Energy Savings (Quads)	Full-Fuel-Cycle Savings (Quads)	Energy Cost Savings (2016 \$ billion)	CO₂ Reduction (MMT)
Commercial					
Annual 2030	0.10	0.26	0.28	2.24	17.57
Annual 2040	0.13	0.32	0.34	2.54	21.48
Cumulative 2010-2030	1.18	3.14	3.30	27.53	208.78
Cumulative 2010-2040	2.34	6.10	6.41	51.59	405.51
Residential					
Annual 2030	0.15	0.28	0.30	3.14	18.38
Annual 2040	0.17	0.33	0.35	3.45	21.46
Cumulative 2010-2030	1.87	3.62	3.86	41.19	234.52
Cumulative 2010-2040	3.48	6.72	7.17	74.34	435.43
Total					
Annual 2030	0.25	0.55	0.58	5.37	35.96
Annual 2040	0.30	0.66	0.69	5.98	42.93
Cumulative 2010-2030	3.06	6.76	7.16	68.72	443.30
Cumulative 2010-2040	5.82	12.82	13.58	125.93	840.94

Note: The following states are excluded from the analysis: AK, CA, HI, KS, MO, MS (residential only), ND, OR, SD, and WA. See section 2.1.3 for details.

⁵ Energy Information Administration's Annual Energy Outlook projects new floor space added in the future. Accessed at: <http://www.eia.gov/forecasts/aeo/>.

⁶ EPA's Greenhouse Gas Equivalencies Calculator: <https://www.epa.gov/energy/greenhouse-gas-equivalencies-calculator>

Acknowledgments

The authors would like to thank David Cohan and Jeremy Williams of the Department of Energy for their guidance and oversight throughout the completion of this assessment. The authors would also like to thank Isaac Elnecave (MEEA), Ken Baker (NEEA), Darren Port and Carolyn Sarno (NEEP), Lauren Westmoreland (SEEA), Richard Morgan (SPEER), Jim Myers (SWEEP), and Allen Lee (Cadmus) for providing assistance during the assessment and reviewing the report. A special thanks to Lowell Ungar of ACEEE who served as a sounding board for ideas on the methodology. The authors appreciate the contributions of PNNL staff including Todd Taylor, Vrushali Mendon, Pam Cole, Mingjie Zhao, Jian Zhang, and Mike Rosenberg.

Acronyms and Abbreviations

ACEEE	American Council for an Energy-Efficient Economy
AEO	Annual Energy Outlook
AIA	American Institute of Architects
BECP	Building Energy Codes Program
BTO	Building Technologies Office
Btu	British Thermal Unit
DHW	Domestic Hot Water
DOE	Department of Energy
ECPA	Energy Conservation and Production Act
EIA	Energy Information Administration
EUI	Energy Use Intensity
FFC	Full-Fuel Cycle
ICC	International Code Council
IECC	International Energy Conservation Code
LED	Light Emitting Diode
LEED	Leadership in Energy and Environmental Design
MEEA	Midwest Energy Efficiency Alliance
MMT	Million Metric Tons
NEEA	Northwest Energy Efficiency Alliance
NEEP	Northeast Energy Efficiency Partnerships
NEMS	National Energy Modeling System
NIA	National Impact Analysis
NOMAD	Naturally Occurring Market Adoption
PNNL	Pacific Northwest National Laboratory
REEO	Regional Energy Efficiency Organization
SEEA	Southeast Energy Efficiency Alliance
SPEER	South-central Partnership for Energy Efficiency as a Resource
SWEEP	Southwest Energy Efficiency Project
SWH	Service Water Heating

Contents

Executive Summary	iii
Acknowledgments.....	vi
Acronyms and Abbreviations	vii
1.0 Introduction	1
2.0 Methodology.....	3
2.1 Analysis Framework	3
2.1.1 Scope of Analysis.....	4
2.1.2 Rolling Baseline Approach	5
2.1.3 Code Effective Date	6
2.1.4 Code-to-Code Savings.....	6
2.1.5 Savings Realized in the Field	8
2.1.6 Floor Space Multiplier	9
2.2 Calculation of Incremental, Annual, and Cumulative Savings	9
2.3 Sample Calculation	10
3.0 Results	12
4.0 References	21
Appendix A – Model Inputs	A.1
Appendix B – Site Energy Savings By Fuel Type.....	B.1
Appendix C – Maximum Potential Savings.....	C.1

Figures

ES.1 Codes Impact Analysis Framework	iii
1 Codes Impact Analysis Framework	4
2 Incremental Savings Calculation.....	4

Tables

ES.1 Summary of Impact of Energy Codes	v
1 With No Mandatory State-wide Code or Enforcement Restrictions	5
2 Example Calculation of Incremental, Annual, and Cumulative Savings for One State.....	11
3 Summary of Energy Codes Impact	13
4 Site Energy Savings (TBtu)	14
5 Primary Energy Savings (TBtu).....	15
6 FFC Energy Savings (TBtu).....	16
7 Discounted Consumer Cost Savings (Billion \$ 2016).....	17
8 Avoided CO ₂ Emissions (MMT).....	18
9 Annual and 5-Year Cumulative Savings.....	19
10 Impact of Codes from 2010-2016	20
A.1 Commercial Codes Adoption Classification by State	A.2
A.2 Residential Codes Adoption Classification by State.....	A.4
A.3 Commercial Future Code Edition Energy Reduction Factors (90.1-2013 = 1.00).....	A.6
A.4 Residential Future Code Edition Energy Reduction Factors (2015 IECC = 1.00).....	A.7
A.5 Future Code Edition Savings	A.7
A.6 Commercial Floor Space Scaling Factors 2011-2014.....	A.8
A.7 Residential Stock Survival Factors	A.8
B.1 Electricity Site Energy Savings by State (TBtu).....	B.1
B.2 Natural Gas Site Energy Savings by State (TBtu)	B.2
B.3 Fuel Oil Site Energy Savings by State (TBtu)	B.3
C.1 Summary of Energy Codes Impact with 100% Compliance.....	C.1

1.0 Introduction

Building energy codes regulate the energy efficiency of new construction and major renovations of buildings. Energy codes have been in place in one form or another since the 1970s and became part of official federal policy in 1992 with the amendment¹ of the Energy Conservation and Production Act (ECPA). The U.S. Department of Energy's (DOE's) Building Energy Codes Program (BECP) was created in response to congressional direction in ECPA to promote energy efficiency in buildings through energy codes. Since then, BECP has supported the development and adoption of model energy codes, and encouraged compliance with those codes through various educational and tool-development activities.

Model codes are codes developed by a national consensus process and made available for adoption by states and local jurisdictions. The model codes of interest in this report are the International Energy Conservation Code (IECC)² for residential and ASHRAE Standard 90.1³ for commercial as these are explicitly referenced in the amended provisions of ECPA and are the basis for the vast majority of U.S. state codes.

The most recent three editions of the IECC and ASHRAE Standard 90.1 have the potential to generate almost a 30% reduction in energy use compared to codes a decade ago (Halverson et al. 2014, Mendon et al. 2015). Together with this rapid progress of codes in the recent past, the President's Climate Action Plan and the Clean Power Plan have generated increased interest in understanding the magnitude of the impact of energy code activities as a whole.

To respond to this interest, PNNL, funded by DOE's Building Energy Codes Program, conducted an assessment of the national impact of building energy codes from 2010-2040. This report describes the methodology and presents the results of the assessment. The starting point of 2010 is chosen because it coincides with the start year for the goals established in the DOE Building Technologies Office's (BTO) Multi-Year Program Plan (BTO 2016). The current assessment builds upon previous analysis, through which PNNL evaluated the historical impacts of buildings energy codes from 1992 through 2010 (Livingston et al. 2014).

The start year of the analysis is a sensitive input. Codes have been in existence since the 1970s and the BECP has been in existence since 1992. Buildings constructed earlier than 2010 and complying with earlier codes have been generating savings and will continue to generate savings in the future. By picking the start year as 2010, savings from the previous years are not reflected in this assessment. If the start year were 1992, for example, savings accrued in 2010 and future years would increase significantly. Thus, the overall impact of energy codes in this assessment can be considered conservative. This is particularly true because the analysis does not include potential savings from states whose energy codes are fundamentally different from the national model energy codes and states which have neither a state-wide code nor significant adoption and enforcement activities by local jurisdictions.

¹ Energy Conservation and Production Act (Pub. L. No. 94-385), as amended by the Energy Policy Act of 1992 (Pub. L. No. 102-486).

² See www.iccsafe.org.

³ See www.ashrae.org.

Section 2.0 of this report describes the overall technical approach. Results are presented in Section 3.0. Appendix A provides details on the inputs used in the assessment. Appendix B provides further breakdown of the energy savings results by fuel type. Appendix C shows the impact of codes if all the potential savings from a code were realized in the field.

2.0 Methodology

Model energy codes follow a three-phase cycle that starts with the development of a new model code, continues with the adoption of the new code by states and local jurisdictions, and finishes when newly constructed buildings are required to comply with the new code. The contribution of all three phases on the overall impact of the code is considered in this assessment. Once a new model code is developed, states need to take action to formally adopt the new code. After the new code is adopted, savings⁴ are realized in the field only when new buildings (or additions and alterations) are constructed to comply with the new code. Delayed adoption of a new model code and incomplete compliance with all the code's requirements erode potential savings.

This analysis uses a “rolling baseline” in which savings are based on the difference in energy efficiency between a new code and its immediate predecessor. When a new code is adopted, the version it replaced becomes the baseline against which savings are calculated. This changes with each new code, thus a “rolling baseline.” A detailed discussion about the rolling baseline can be found in section 2.1.2.

In this analysis, potential savings between one code and its successor do not include savings resulting from improvements in equipment efficiency mandated by federal rulemakings. DOE rulemakings set minimum efficiency levels for certain heating, ventilating, and air conditioning (HVAC), and service water heating (SWH) equipment. These improvements in equipment efficiency would result regardless of whether a new code is enforced, and are therefore not attributable to the energy code.

There are many beyond-code programs, such as utility incentive programs, Energy Star (EPA 2016), LEED (USGBC 2016), as well as other locally- and state-funded programs that promote energy efficiency in buildings. Such programs have an impact on the energy efficiency of the building stock that can be considered separate from the code impact. For example, the first phase of the DOE residential field study (BECF 2016a) showed that windows installed in new homes consistently and significantly exceeded code requirements in all participating states. This higher level of window performance might be driven by certain beyond-code programs but it is very difficult to separate the impact of these programs from the impact of codes. Energy codes remain the primary mechanism through which improvements in energy efficiency are enforced on the majority of the building stock. In this analysis, potential improvement between successive codes is entirely attributed to the new code. No credit is taken for improvements beyond the requirements within the energy code.

2.1 Analysis Framework

This section describes the analytical framework of the assessment and provides further detail on how the savings calculation is structured. Figure 1 provides a schematic overview of the framework. The assessment begins with the adoption of codes at the state level starting in 2010. In each year, potential savings are calculated by subtracting the energy use intensity (EUI) of the current code from the EUI of the previous code. Next, potential savings are de-rated by realization rate to determine savings realized in the field. Finally, the de-rated savings are multiplied by the floor space added in a given year to calculate the incremental savings in that year (Figure 2). The process repeats each year starting with the evaluation of the code currently in place and the code that was in place before. Annual and cumulative savings are

⁴ Assuming the new code is more stringent than the previous code per DOE's Determination (<https://www.energycodes.gov/determinations>).

calculated from incremental savings to determine the overall impact. More details on the calculation are provided in the following sections.




Figure 1. Codes Impact Analysis Framework

$$\text{Incremental Savings} = \text{Potential EUI Savings} \times \text{Savings Realization Rate} \times \text{Floor space}$$

Figure 2. Incremental Savings Calculation

2.1.1 Scope of Analysis

This cannot be considered a full national analysis because several states were excluded for one of two reasons:

1. They do not adopt a code at the state level, or a state-wide code exists but it is not mandatory or there are special restrictions on enforcement. States in this category are Alaska, Hawaii, Kansas, Missouri, Mississippi (residential only), North Dakota, and South Dakota. Conversely, Arizona, Colorado, and Wyoming do not enforce state-wide codes, but their largest jurisdictions have adopted recent energy codes so they are included and treated as if they have state-wide codes in this study. Table 1 provides details on the treatment of states with no mandatory state-wide codes or enforcement.
2. They have energy codes significantly different in format and content than ASHRAE 90.1 or the IECC model codes, so the EUIs developed for this analysis could not be applied to their energy codes. Developing custom EUIs for these states was beyond the scope of this analysis. California, Oregon, and Washington are in this category. Florida previously had a highly-customized state code, but recently moved to a code based on the 2012 IECC and is therefore included in the analysis. Detailed information on adoption inputs can be found in Appendix A.

Table 1. With No Mandatory State-wide Code or Enforcement Restrictions

State	Mandatory Enforcement of State-wide Code	Restrictions	Use of Populous Jurisdictions or Cities as Surrogate for State-wide Code
Alaska	Yes	Commercial: only buildings in the transportation, public facilities, and education department are regulated. Residential: Must comply with state code if state financial assistance is used in construction.	No
Arizona	No		Yes (Phoenix, Tucson)
Colorado	No		Yes (Denver, Aurora, and Boulder County)
Hawaii	Yes	Only enforced for commercial and residential structures over three stories in height.	No
Kansas	No		No
Missouri	No		No
Mississippi (residential only)	No		No
North Dakota	No		No
South Dakota	No		No
Wyoming	No		Yes (Jackson and Cheyenne Counties)

Taken together, the excluded states account for 19.5% of new commercial floor space and 16.1% of new residential floor space projected to be constructed between 2011 and 2040 in the United States. While developing associated savings estimates would require EUIs that don't currently exist, it is safe to say that the overall national impact of building energy codes is substantially higher than the results reported in this study.

2.1.2 Rolling Baseline Approach

The rolling baseline used in this study assumes the predecessor code of each newly adopted code as the baseline for savings analysis. Alternatively, a fixed baseline would assume that the first code in the study period – the one in place in a state in 2010 in this study – was the baseline for all future codes. Since this study uses the difference between the baseline EUI and the current code EUI to determine savings, it is clear that the rolling baseline results in much smaller, more conservative savings estimates. However, the fixed baseline approach was rejected as overly optimistic because it implicitly assumes that building efficiency never increases in the absence of changes to the energy code. Given a variety of market drivers for efficiency that are known to exist (product competition, utility rebates, above-code programs, etc.) that assumption was deemed insupportable.

A third approach, used in some past analyses from BECP as well as other organizations' code impact studies, is to assume an increasingly efficient baseline intended to represent "normally occurring market adoption" (NOMAD) of efficiency in the absence of codes improvements. Assumptions about NOMAD levels are typically based on expert opinion and are thus inherently subjective, ranging from high to low depending on individual beliefs about how much efficiency will improve over time.

More important for the current study, a NOMAD baseline is unrelated to code development and adoption that have actually occurred. Code adoption, code-to-code savings, and compliance rates in the presence of codes are known in many cases. Relying on what is known for developing the baseline makes the analysis more robust and defensible. At the same time, all assumptions about future code levels are ultimately subjective; in the absence of a perfect way to predict the future, this study opted for the approach most closely tied to the development/adoption/implementation cycle.

It should be noted that an inherent consequence of choosing the predecessor code as the baseline is that a state that adopt codes in a timely fashion could save less energy than a state that delays new code adoption if the new code edition saves less than the previous code. This effect is discussed in greater detail in Section 3.0.

2.1.3 Code Effective Date

For this analysis, savings are generated for the first time when a state adopts a code newer than the one in place in 2010. A code was considered to be in place in a given year if the code was effective on or before July 1st of that year⁵. For future code adoptions, states are classified into four categories based on their historical rate of adoption:

1. **Timely:** State adopts new code within one code cycle. Future adoption lag = 1 year.
2. **Medium Slow:** State adopts new code within two code cycles. Future adoption lag = 4 years.
3. **Very Slow:** State adopts new code after two code cycles. Future adoption lag = 7 years.
4. **Not Applicable:** States with no state-wide code, no code enforced in jurisdictions within the state or with minimal relationship to the national model codes.

Based on the above classification, the year in which a state is expected to adopt a future code depends on the adoption lag and the code year. For example, Illinois, classified as timely, is anticipated to adopt the 2018 IECC in the year 2019 (a one year lag). The code year for both residential and commercial is the IECC year (and not the year in which the code book is published). For example, the code year for the 2015 IECC is 2015 even though the 2015 IECC was published in 2014. The commercial code year is based on the IECC and not on 90.1 because most states adopt the IECC (to which 90.1 is an alternate compliance path).

2.1.4 Code-to-Code Savings

Once the code in place in a given year for each state is known or assigned, code-to-code savings can be calculated by subtracting the EUI of the new code from that of the previous code. The delta between the code EUIs is used in determining the potential EUI savings in Figure 2. Code EUIs are developed using the process established by DOE for its statutorily-directed “Determinations” that indicate whether a new code will improve energy efficiency in buildings. The most recent commercial and residential determinations and their associated technical reports describe the process in greater detail (Halverson et

⁵ Effective dates for existing codes were based on the information available as of April 1, 2016. Any code adoption actions taken by states after that date are not included in this analysis. For example, if a state announced in May 2016 that it would adopt the 2015 IECC in 2017, this action is not included in the report.

al. 2014, Mendon et al. 2015). The Determination process excludes savings resulting from improvements in equipment efficiency due to federally mandated requirements. Past analyses conducted by PNNL in support of BECP, such as the long-term state benefits analysis for Standard 90.1-2013 (commercial) (ASHRAE 2013) and the cost-effectiveness analysis of the 2015 IECC (residential) (ICC 2015), which used the Determination approach, were leveraged to create the EUIs used in this analysis. Further detail on how commercial and residential EUIs are developed is provided below.

Commercial Code EUIs. There are four editions of ASHRAE Standard 90.1—2004, 2007, 2010, and 2013—for which PNNL determined EUIs. As part of the long-term benefits analysis for 90.1-2013, the Determination method was used to calculate the EUI in each state for 90.1-2013 and 90.1-2010. Simulations were performed for each climate zone in every state and the results were weighted by forecasted new construction area to produce state-level EUIs. These results are used in this analysis.

Previous Determination analyses for 90.1-2007 and 90.1-2004 could not be used directly to obtain EUIs for those Standards because when those analyses were performed, the federally mandated equipment efficiencies differed from when the Determination analysis for 90.1-2013 was conducted. To correctly calculate the EUIs for 90.1-2007, savings percentages between 90.1-2010 and 90.1-2007 calculated in the Determination analysis of 90.1-2010 are applied to the state-level EUIs of 90.1-2010. A similar process is followed to determine EUIs for 90.1-2004. This process of using savings percentages ensures that the EUIs of the four 90.1 editions (2004 through 2013) are consistent with each other in terms of the published Determination savings. EUIs for codes older than 90.1-2004 are calculated using a historical index of commercial code improvements developed by PNNL (BTO 2016).

To develop EUIs for future code editions (90.1-2016 and onwards), PNNL examined BTO's Technology Roadmap reports for envelope, lighting, HVAC and SWH (BTO 2015, 2014a,b,c). PNNL also reviewed AIA's 2030 Goal (AIA 2030) and the goals set by the Standard 90.1 development committee for each edition. Appendix A provides a more detailed discussion of future code EUIs. Standard 90.1-2013 achieved a 7.6% reduction over 90.1-2010, and a savings goal of approximately 5-10% better than the 2013 edition was set for the 2016 edition of Standard 90.1.

Based on this information, PNNL elected to use 5% as the reduction in EUI for the next cycle of commercial codes (90.1-2016 and 2018 IECC). Beyond the next cycle, it is difficult to predict the increases in stringency. Different reduction percentages are applied to different end-uses depending on the projected technological progress. The plug and process end-use is conservatively projected to see no reduction at all in future code editions. The impact of renewable technologies is not included in future code editions. After applying reduction percentages to end-uses, the overall reduction per cycle is between 4% and 5% (including plug loads). Detailed inputs for historical and future code edition efficiency levels can be found in Appendix A.

States can adopt either the commercial IECC or the corresponding 90.1 Standard—both are updated every three years. Each edition of the IECC has historically allowed the corresponding 90.1 edition as an alternate compliance path, and it is assumed that that practice will continue. In this analysis, the EUIs developed for 90.1 are used to represent corresponding editions of 90.1 and the IECC, because equivalent EUIs for the IECC are not available and their development is beyond the scope of this analysis. For example, 90.1-2010 and 2012 IECC are represented by a single state-level EUI.

States often amend certain sections of the IECC or 90.1 when adopting the code. Such amendments to commercial codes are not factored into the EUIs used in this analysis.

Residential Code EUIs. PNNL used the EUIs developed for four editions of the residential IECC—2006, 2009, 2012, and 2015—as part of the state cost-effectiveness analysis (Mendon et al. 2016). EUIs from the past analysis are used in the current assessment. The impact of state-specific code amendments were not incorporated into the EUI analysis because amended code EUIs were not available for all code editions adopted by a particular state. Plug loads are not currently regulated by residential codes and are therefore not included in the analysis.

As with the commercial codes, EUIs of future editions of residential codes are determined by reviewing BTO's Technology Roadmaps. In recent editions, the 2015 IECC saved less than 1% relative to the 2012 version (Mendon et al. 2015) but the 2012 version saved 24% relative to the 2009 and the 2009 saved 11% relative to the 2006 (Lucas et al. 2013). Based on this information, a 5% reduction is chosen for the 2018 IECC compared to the 2015 IECC. For future code editions, different reduction percentages are applied to different end-uses depending on the projected technological progress. This results in approximately 4% to 5% reduction in EUI per cycle for future code editions. Further details on the historical and future code edition efficiency levels can be found in Appendix A.

2.1.5 Savings Realized in the Field

Energy code compliance is crucial to realizing the savings potential embedded within code requirements. While many past studies have attempted to quantify compliance with residential and commercial codes, a literature survey of past commercial compliance studies (Bartlett et al. 2016) found several problems including too-small sample sizes, sample bias, difficulty in accessing compliance documentation, and most importantly in the context of this analysis, the lack of a uniform definition of compliance. Past field studies measured the percent of requirements complied with relative to the total number of requirements, a metric aligned with how building officials see compliance but not tied to energy savings. The current analysis defines compliance as a savings realization rate equal to the fraction of the total potential savings that is achieved in the field. The savings realization rate determined in this manner is used to calculate the incremental savings in a given year, as shown in Figure 2.

DOE is currently conducting a residential field study designed to determine whether an investment in building energy code education, training, and outreach programs can produce a significant and measurable change in residential building energy savings realized in the field (BECP 2016a). This field study takes into account the sample size required to make statistically significant statements about the energy savings potential realized in the field at the state level. One of the study outcomes is a comparison of the observed EUI for an entire state with that of a hypothetical sample that fully complies with the code. Using these results, it is possible to determine the fraction of EUI savings realized in the field.

The results from the first phase of the residential field study show that states realized more than 100% of expected savings for codes that had been adopted at least two years after they had been published. Of the eight states in the field study, the seven with 2012 IECC or 2009 IECC had savings realization rates over 100%. Only one state had adopted the 2015 IECC, which was published just one year prior to adoption and measurement in the field study, and its realization rate was 89%. Based on the limited data in the field study, PNNL hypothesized that a relationship could be established between the publication date of the code and the savings realization rate—the longer the delay in adopting a code, the higher the

realization rate. For example, if a state adopted the 2009 IECC in the year 2015, the realization rate in 2015 would be very close to 100%. However, if a state adopted the 2015 IECC in 2016, the realization rate would be lower. The underlying theory is that the savings realized in the field seem to depend more on the time that has passed since the code was published than on the time passed since the code was adopted. Based on this hypothesis, a realization rate of 80% was chosen as a conservative estimate in the first year after the code is published. The realization rate was then increased asymptotically every year, approaching 100% at the end of 10 years. When a new code becomes effective, for example five years after the previous code, the realization rate is reset to 80% for Year 1 of the new code. This approach was applied to all residential codes and states.

Similar data for savings realized in the field in commercial buildings is not available. DOE is in the process of launching a commercial codes field study to better understand the fraction of potential savings realized from codes in commercial buildings. A pilot study conducted by PNNL (Rosenberg et al. 2016) analyzed lost energy savings from a sample of nine small office buildings in the Pacific Northwest region. The study found the maximum fraction of lost energy savings to be approximately 12%, or in other words, the lowest savings realization rate was 88%. For this analysis, a very conservative realization rate of 50% is chosen for the first year after the commercial code is published, i.e., only 50% of the potential savings are realized in the first year. For example, timely states with a future adoption time lag of one year will realize only 50% of the savings from the new code in the first year. The realization rate then increases asymptotically every year, approaching 80% in year 10. This approach is applied to all commercial codes and states.

2.1.6 Floor Space Multiplier

The incremental savings depend upon the amount of new floor space in the state that is built to the code. New floor space constructed in a given year is used to determine the incremental savings in a given year, as shown in Figure 2. Estimates of new residential and commercial floor space constructed each year were developed in a previous analysis (Livingston et al. 2014), which melded several datasets to develop a continuous stream of historical and projected annual floor space construction from 1992 through 2040. Projections were based on Census division-level floor space data from the 2012 edition of the Energy Information Administration's (EIA) Annual Energy Outlook (AEO). The AEO provides projections of U.S. energy markets and serves as a reference for performing future energy and economic analyses.

The same methodology from the previous analysis is used to update floor space data for this analysis, with the underlying data from the 2015 edition of the AEO (EIA 2015) used to develop projections. Adjustments are made to the commercial and residential floor space streams based on the AEO 2015 data. Appendix A provides a detailed description of the changes to the floor space calculation.

Shrinkage of savings over time because of floor space demolition is not included in the analysis because it is assumed that the average lifespan of a building is longer than the length of this analysis (buildings built in 2011 will last beyond 2040).

2.2 Calculation of Incremental, Annual, and Cumulative Savings

Figure 1 and Figure 2 describe how incremental savings in a single year are calculated. Savings from code adoptions are generated throughout a building's life because in the absence of a new code, the

building would have been built to an older, less energy efficient code and would have consumed more energy every year of its life. Thus, buildings built in the past are still generating savings today. Savings from past code adoptions add to the savings generated from new construction in a given year. In this analysis, three different types of savings are calculated and tabulated for each year in the study:

1. **Incremental savings:** Savings accruing only from new floor space added in a given year. These savings are simply a product of the code-to-code savings in a given year and the floor space added in that year.
2. **Annual savings:** Savings accruing from not only new floor space added in the given year but also from previous code adoptions and new floor space construction that occurred in the study period up to that year. Annual savings account for code actions that affected floor space added in previous years, and that continues to generate savings in the current year.
3. **Cumulative savings:** The sum of annual savings over all the years in the study period.

Savings reduction occurring from degradation of energy saving features over time is ignored for this analysis. For example, lighting occupancy sensor control savings could reduce over time because of degrading electronic components (relays, sensors, etc.) or there may be an increase in infiltration due to wear and tear of the envelope. These effects are ignored in the analysis because they will equally affect the new code and the baseline, thus having a negligible net effect on the savings. A sample calculation in the next section attempts to explain the savings calculation for a single state.

2.3 Sample Calculation

Table 2 gives an example of how incremental, annual and cumulative savings are calculated in this analysis. The calculation is performed for energy savings only for a single state for the period beginning in 2010 and ending in 2020. For simplicity, generic values are chosen for code-to-code savings, savings realization rates, and the amount of floor space added each year. Row 1 indicates the code edition. The calculation starts with code edition 1 in place in 2010. In 2011, a new code is adopted giving rise, for the first time, to energy savings indicated in row 2. These energy savings arise from the fact that code edition 2 has a higher efficiency level compared to code edition 1. Row 3 shows the savings realization rate. Note that it improves each year a code is in place and then gets lower whenever a new code is adopted. Row 4 shows the realized savings, calculated as code-to-code savings (Row 2) times the realization rate (Row 3). Row 5 shows the floor space added in a given year, which, for this example, is assumed to be a million square feet (sf) every year.

Table 2. Example Calculation of Incremental, Annual, and Cumulative Savings for One State

Row	Year	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
1	Code Edition	1	2	2	2	3	3	3	3	4	4	4
2	Code-to-Code Savings, kBtu/sf	-	7.0	7.0	7.0	6.0	6.0	6.0	6.0	5.0	5.0	5.0
3	Realization Rate	-	0.7	0.8	0.9	0.7	0.8	0.9	0.95	0.7	0.8	0.9
4	Realized Savings, kBtu/sf	-	4.9	5.6	6.3	4.2	4.8	5.4	5.7	3.5	4	4.5
5	New floor space added, thousand sf	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000	1000
Savings, billion BTUs												
	Year of accounted savings →	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
	Year floor space is added ↓											
6	2010	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7	2011	0.0	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9	4.9
8	2012	0.0	0.0	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6
9	2013	0.0	0.0	0.0	6.3	6.3	6.3	6.3	6.3	6.3	6.3	6.3
10	2014	0.0	0.0	0.0	0.0	4.2	4.2	4.2	4.2	4.2	4.2	4.2
11	2015	0.0	0.0	0.0	0.0	0.0	4.8	4.8	4.8	4.8	4.8	4.8
12	2016	0.0	0.0	0.0	0.0	0.0	0.0	5.4	5.4	5.4	5.4	5.4
13	2017	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5.7	5.7	5.7	5.7
14	2018	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.5	3.5	3.5
15	2019	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.0	4.0
16	2020	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4.5
17	Incremental	0.0	4.9	5.6	6.3	4.2	4.8	5.4	5.7	3.5	4.0	4.5
18	Annual	0.0	4.9	10.5	16.8	21.0	25.8	31.2	36.9	40.4	44.4	48.9
19	Cumulative (sum of Annual Savings from 2010 thru 2020)											280.8

Note: Generic values are used in this table to demonstrate the calculation.

Rows 6 through 16 calculate the incremental savings in each year, i.e., the realized savings (Row 4) times the floor space added in that year (Row 5). There are obviously no incremental savings in 2010 because the code in place did not change. In 2011, however, a new code is adopted, and incremental savings will be generated. In 2012, there are both, incremental savings from new floor space added in that year, and savings from buildings constructed in 2011 will continue into 2012 and beyond. These continuing savings can be seen in Rows 7-15 of Table 2 where the initial savings number in each row is repeated each year. On Row 8, for example, buildings built in 2012 deliver 5.6 MMBtu of savings the first year. But they continue to deliver this same 5.6 MMBtu of savings in all subsequent years (moving horizontally to the right across the row).

Row 17 shows the incremental savings in every year and Row 18 shows the annual savings in every year. For 2011 the incremental and annual savings are the same, but for 2012, the annual savings are larger because they are the sum of the previous year's annual savings and the current year's incremental savings. Annual savings at the end of the study period are much larger than at the beginning of the study period. For example, the annual savings in year 2020 are much larger than in 2015 because the floor space added each year in the intervening period (2016-2020) generates savings that will become part of the annual savings in 2020. Finally, Row 19 shows the cumulative savings for the entire period, a sum of the annual savings (Row 18) from 2010 through 2020.

3.0 Results

This section presents the results of the assessment in terms of site energy savings, primary energy savings (including transmission, delivery, and generation losses), full-fuel cycle (FFC) savings⁶, financial benefits to consumers (utility bill savings), and avoided carbon emissions. The conversion from site energy savings to source energy savings, FFC savings, and reduced carbon emissions is performed by applying site-to-source and environmental conversion factors developed through DOE's Appliance and Equipment Standards Program⁷. These factors take into account the correlation between regional variation in energy consumption and emissions intensity from electricity production. Financial benefits are calculated by applying historical and future fuel prices to site energy savings and by discounting future savings to 2016 dollars. Historical and future real fuel prices are obtained through EIA's AEO 2015 report (EIA 2015). A real discount factor of 5% is applied to discount future energy cost savings (federal rulemaking analysis typically uses boundary discount factors of 3% and 7%; a 5% discount factor is chosen as a midpoint). Further details on savings conversions can be found in Appendix A.

Table 3 summarizes the impact of energy codes aggregated across all the states included in this analysis. Savings are combined from all fuel types (electricity, natural gas, and fuel oil). Annual savings, as defined in section 2.2, are shown for 2030 and 2040, and cumulative savings are shown for 2010-2040. Savings are further broken out into residential and commercial codes. Energy codes save 12.82 quads of primary energy, \$126 billion dollars in consumer cost, and reduce 841 million metric tons (MMT) of CO₂ on a cumulative basis from 2010-2040. Primary energy savings, FFC savings, and CO₂ reductions are split almost equally between commercial and residential buildings, while energy cost savings are roughly 35% higher in residential than commercial. As described in section 2.1.1, the results shown here are substantially lower than the potential savings from energy codes in the entire U.S. because several states were not included.

Table 4 through Table 8 show the energy and environmental impacts for each state. Site, primary, and FFC energy savings (TBtu), energy cost savings (billion \$ 2016), and CO₂ reduction (MMT) are shown in the tables for each state. Commercial and residential savings are shown separately. It can be seen that certain states, such as Texas, Florida, and a few others, have much higher total savings than other states reflecting their relatively higher past and projected new floor space construction. The additive nature of code savings gives rise to significantly higher cumulative savings for these states at the end of the study period.

As explained in section 2.1.2, the rolling baseline approach uses the previous code in place as the baseline. This can give rise to non-intuitive results, such as states which adopt codes in a timely manner saving less energy on a cumulative basis than states which adopt codes at a moderate or slow pace (given equal floor space and same starting code editions). For example, Illinois is a timely adopter of new codes, and Michigan adopts codes at a moderate pace. Comparing the residential cumulative primary energy savings between these states, it can be seen that Illinois saves 111 TBtu whereas Michigan saves 262 TBtu. The higher savings from Michigan result from two main differences:

⁶ This includes fuel extraction, processing, conveyance to the retail distribution center, and delivery to power plants

⁷ <http://energy.gov/eere/buildings/appliance-and-equipment-standards-program>

- a. Michigan has the 2003 IECC in 2010 (analysis start year) and Illinois has the 2009 IECC in 2010. Michigan will therefore save more energy when it adopts a new code for the first time in the analysis period.
- b. Michigan adopts 2009 IECC in 2011 and 2015 IECC in 2016 and stays on the 2015 IECC until 2022. The predecessor for the 2009 IECC for Michigan is the 2003 IECC, and later, the predecessor for the 2015 IECC is the 2009 IECC. Illinois adopts 2012 IECC in 2013 and then 2015 IECC in 2016. The predecessor for the 2012 IECC is 2009 IECC for Illinois, and for the 2015 IECC it is the 2012 IECC. These combinations will result in much higher savings for Michigan compared to Illinois.

Similarly, other states that are moderate and slow adopters of codes are likely to accumulate higher savings per unit of floor space.

The national savings in each year and the cumulative savings at the end of every five years are presented in Table 9. Table 10 shows the impact of codes from 2010 through 2016, i.e., savings only from code actions between 2010 and 2016 and assuming no savings from new floor space added after 2016. Annual savings in 2016 are carried over each year until 2040 to calculate the cumulative savings from 2010 to 2040. The impact of code activities between 2010 and 2016 is equal to nearly 5 quads of primary energy, 53 billion dollars in consumer cost savings, and 319 MMT of avoided CO₂ emissions.

Table 3. Summary of Energy Codes Impact

Sector	Site Energy Savings (Quads)	Primary Energy Savings (Quads)	FFC Savings (Quads)	Energy Cost Savings (2016 \$ billion)	CO ₂ Reduction (MMT)
Commercial					
Annual 2030	0.10	0.26	0.28	2.24	17.57
Annual 2040	0.13	0.32	0.34	2.54	21.48
Cumulative 2010-2030	1.18	3.14	3.30	27.53	208.78
Cumulative 2010-2040	2.34	6.10	6.41	51.59	405.51
Residential					
Annual 2030	0.15	0.28	0.30	3.14	18.38
Annual 2040	0.17	0.33	0.35	3.45	21.46
Cumulative 2010-2030	1.87	3.62	3.86	41.19	234.52
Cumulative 2010-2040	3.48	6.72	7.17	74.34	435.43
Total					
Annual 2030	0.25	0.55	0.58	5.37	35.96
Annual 2040	0.30	0.66	0.69	5.98	42.93
Cumulative 2010-2030	3.06	6.76	7.16	68.72	443.30
Cumulative 2010-2040	5.82	12.82	13.58	125.93	840.94

Note: The following states are excluded from the analysis: AK, CA, HI, KS, MO, MS (residential only), ND, OR, SD, and WA. See section 2.1.3 for details.

Table 4. Site Energy Savings (Tbtu)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	2.54	3.08	30.20	58.40	3.06	3.36	34.34	66.56	5.60	6.43	64.54	124.96
Arizona	6.52	7.59	85.71	156.60	4.67	5.55	62.05	113.53	11.19	13.14	147.76	270.13
Arkansas	1.48	1.75	17.11	33.32	1.31	1.52	15.18	29.41	2.80	3.27	32.29	62.73
Colorado	4.34	5.06	53.35	100.54	8.19	9.27	101.07	188.84	12.53	14.33	154.42	289.38
Connecticut	1.14	1.47	12.87	26.05	1.29	1.52	17.02	31.18	2.42	2.99	29.89	57.22
Delaware	0.27	0.35	3.04	6.16	0.70	0.85	8.83	16.62	0.97	1.20	11.87	22.79
District of Columbia	0.46	0.59	5.31	10.60	0.22	0.28	2.90	5.42	0.68	0.87	8.21	16.02
Florida	8.96	11.52	101.29	204.44	5.64	7.40	73.77	139.80	14.60	18.91	175.07	344.24
Georgia	4.42	5.80	49.78	101.31	3.83	4.61	52.32	94.90	8.25	10.41	102.10	196.21
Idaho	0.64	0.84	7.39	14.84	2.10	2.48	28.66	51.70	2.74	3.31	36.05	66.54
Illinois	3.13	4.22	37.51	74.64	2.32	2.92	30.91	57.45	5.45	7.15	68.41	132.09
Indiana	2.97	3.96	25.28	60.18	5.06	5.71	63.12	117.29	8.03	9.67	88.41	177.46
Iowa	0.89	1.23	10.19	20.90	1.20	1.56	15.33	29.31	2.09	2.79	25.52	50.21
Kentucky	1.63	2.05	19.79	38.34	1.33	1.61	16.53	31.34	2.96	3.66	36.32	69.68
Louisiana	1.42	1.86	15.90	32.43	1.89	2.30	21.58	42.68	3.31	4.16	37.48	75.11
Maine	0.52	0.67	6.07	12.11	0.98	1.17	12.02	22.87	1.50	1.84	18.10	34.98
Maryland	1.41	1.96	16.79	33.81	1.25	1.64	17.24	31.89	2.66	3.60	34.03	65.71
Massachusetts	1.11	1.53	12.61	25.96	1.92	2.53	23.68	46.25	3.02	4.06	36.29	72.21
Michigan	3.81	4.61	49.80	92.20	8.03	8.76	102.25	186.61	11.84	13.38	152.05	278.81
Minnesota	2.21	2.76	25.95	50.98	5.37	6.02	71.83	129.13	7.59	8.77	97.78	180.11
Mississippi	2.52	2.80	30.77	57.38	0.00	0.00	0.00	0.00	2.52	2.80	30.77	57.38
Montana	0.23	0.30	2.60	5.30	0.94	1.14	12.02	22.50	1.18	1.44	14.62	27.80
Nebraska	1.69	1.98	20.27	38.70	1.65	1.87	20.79	38.52	3.34	3.85	41.06	77.21
Nevada	2.01	2.61	22.55	45.82	2.32	2.72	31.77	57.19	4.33	5.33	54.32	103.01
New Hampshire	0.44	0.59	4.75	9.94	0.68	0.83	8.17	15.76	1.12	1.41	12.91	25.70
New Jersey	2.80	3.32	32.03	62.81	7.21	7.89	91.62	167.51	10.01	11.21	123.65	230.32
New Mexico	0.71	0.92	6.75	14.96	1.20	1.37	14.87	27.74	1.91	2.29	21.62	42.70
New York	2.87	3.82	34.40	68.19	6.26	7.10	86.81	154.05	9.13	10.92	121.21	222.24
North Carolina	3.38	4.44	37.78	77.21	4.56	5.63	60.44	111.91	7.94	10.07	98.22	189.12
Ohio	4.96	6.31	48.54	105.21	4.62	5.28	55.49	105.33	9.58	11.59	104.03	210.54
Oklahoma	2.00	2.47	22.29	44.72	3.83	4.27	48.56	89.24	5.83	6.73	70.85	133.96
Pennsylvania	3.19	4.22	33.98	71.38	3.41	4.21	41.06	79.59	6.60	8.43	75.04	150.98
Rhode Island	0.25	0.34	3.03	5.99	0.14	0.19	1.76	3.46	0.39	0.53	4.79	9.45
South Carolina	1.70	2.23	18.82	38.64	2.66	3.24	35.89	65.69	4.36	5.47	54.71	104.33
Tennessee	3.26	3.98	37.90	74.30	3.51	4.18	39.13	77.85	6.77	8.16	77.03	152.15
Texas	11.89	14.91	154.42	289.31	26.37	30.12	340.77	625.02	38.25	45.03	495.19	914.33
Utah	0.86	1.22	9.52	20.03	8.23	8.85	86.82	172.42	9.09	10.07	96.34	192.45
Vermont	0.11	0.14	1.15	2.41	1.05	1.14	13.40	24.40	1.16	1.28	14.55	26.81
Virginia	3.27	4.20	38.26	75.89	3.89	4.62	53.92	96.86	7.17	8.82	92.18	172.75
West Virginia	0.69	0.81	7.74	15.27	0.40	0.47	4.68	9.02	1.08	1.28	12.41	24.29
Wisconsin	2.35	3.03	26.76	53.87	4.08	4.69	45.12	89.27	6.43	7.71	71.87	143.13
Wyoming	0.33	0.40	4.21	7.85	0.61	0.71	8.67	15.30	0.94	1.11	12.88	23.15

Table 5. Primary Energy Savings (TBtu)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	6.89	8.17	82.61	158.19	7.19	7.88	81.98	157.56	14.08	16.04	164.59	315.75
Arizona	19.00	21.64	251.82	455.85	10.77	12.80	142.45	261.20	29.76	34.44	394.27	717.05
Arkansas	3.86	4.47	44.85	86.63	2.81	3.24	32.71	63.15	6.67	7.71	77.56	149.78
Colorado	11.40	12.94	141.62	263.82	11.59	13.40	142.67	268.41	22.99	26.34	284.28	532.23
Connecticut	2.73	3.45	31.37	62.53	1.68	2.03	21.86	40.58	4.41	5.48	53.22	103.11
Delaware	0.67	0.85	7.68	15.34	1.72	2.07	21.84	40.94	2.39	2.92	29.52	56.28
District of Columbia	1.22	1.53	14.41	28.24	0.55	0.67	7.07	13.20	1.77	2.20	21.48	41.44
Florida	26.54	33.01	304.97	604.75	16.28	20.78	216.20	403.70	42.82	53.79	521.17	1008.45
Georgia	12.12	15.35	139.10	277.49	10.03	11.91	138.20	248.79	22.15	27.26	277.30	526.28
Idaho	1.70	2.11	20.06	39.23	2.99	3.64	40.34	73.79	4.69	5.75	60.41	113.02
Illinois	7.24	9.50	88.44	172.92	3.42	4.42	44.03	83.80	10.66	13.92	132.47	256.72
Indiana	6.85	8.92	59.64	138.99	7.52	8.59	94.12	175.14	14.37	17.51	153.76	314.13
Iowa	2.11	2.83	24.69	49.63	2.13	2.78	26.67	51.55	4.24	5.60	51.36	101.18
Kentucky	3.93	4.84	48.00	92.15	3.05	3.67	37.98	71.88	6.97	8.51	85.97	164.04
Louisiana	3.95	4.99	44.88	89.91	4.38	5.30	50.88	99.61	8.33	10.29	95.76	189.51
Maine	1.17	1.48	13.70	27.04	1.21	1.48	14.62	28.23	2.38	2.96	28.32	55.28
Maryland	3.60	4.82	43.80	86.26	3.10	4.02	42.84	78.93	6.70	8.84	86.64	165.19
Massachusetts	2.64	3.53	30.75	61.89	2.53	3.45	29.92	60.35	5.17	6.98	60.67	122.24
Michigan	8.82	10.48	116.60	213.70	11.18	12.33	142.55	260.75	20.01	22.81	259.15	474.44
Minnesota	4.89	5.98	57.91	112.64	9.22	10.34	122.87	221.27	14.10	16.33	180.78	333.91
Mississippi	6.90	7.56	84.99	157.40	0.00	0.00	0.00	0.00	6.90	7.56	84.99	157.40
Montana	0.54	0.68	6.04	12.16	1.28	1.59	16.09	30.60	1.82	2.27	22.13	42.76
Nebraska	4.08	4.70	49.38	93.40	2.95	3.36	37.30	68.98	7.03	8.05	86.67	162.38
Nevada	5.66	7.10	65.18	129.46	4.21	5.04	56.94	103.56	9.87	12.14	122.11	233.02
New Hampshire	1.04	1.34	11.32	23.30	0.85	1.08	10.11	19.90	1.89	2.42	21.42	43.20
New Jersey	6.72	7.84	77.53	150.76	10.71	11.86	135.61	249.08	17.43	19.70	213.15	399.84
New Mexico	1.95	2.42	18.86	40.80	1.89	2.20	23.47	44.00	3.83	4.62	42.33	84.81
New York	6.89	8.93	83.46	163.28	9.47	10.85	130.37	232.71	16.35	19.78	213.82	395.99
North Carolina	9.13	11.62	103.70	208.24	11.64	14.19	155.24	285.64	20.77	25.81	258.94	493.89
Ohio	11.62	14.50	114.80	246.03	6.72	7.80	80.87	153.95	18.34	22.30	195.67	399.98
Oklahoma	5.16	6.20	58.15	115.19	8.13	9.03	104.19	190.35	13.29	15.24	162.33	305.54
Pennsylvania	7.69	9.90	83.59	172.34	5.09	6.42	60.04	118.31	12.77	16.32	143.63	290.65
Rhode Island	0.60	0.78	7.47	14.47	0.19	0.26	2.25	4.56	0.80	1.05	9.72	19.04
South Carolina	4.76	6.02	53.76	108.03	6.96	8.36	94.29	171.56	11.71	14.38	148.06	279.59
Tennessee	8.43	10.10	98.99	192.00	8.28	9.82	92.72	183.88	16.72	19.92	191.71	375.89
Texas	33.21	40.47	435.79	806.50	61.29	69.84	802.73	1462.63	94.50	110.31	1238.52	2269.13
Utah	2.29	3.08	26.60	53.68	12.05	13.15	126.66	253.03	14.34	16.23	153.25	306.72
Vermont	0.24	0.32	2.64	5.44	1.29	1.41	16.33	29.87	1.52	1.73	18.97	35.32
Virginia	8.59	10.73	101.42	198.66	9.82	11.56	136.46	244.22	18.41	22.28	237.88	442.89
West Virginia	1.66	1.94	18.88	36.97	1.00	1.17	11.91	22.82	2.67	3.11	30.80	59.78
Wisconsin	5.23	6.61	60.31	120.01	5.73	6.67	63.28	125.71	10.97	13.27	123.60	245.71
Wyoming	0.80	0.95	10.38	19.19	0.86	1.01	12.12	21.53	1.65	1.96	22.51	40.71

Table 6. FFC Energy Savings (TBtu)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	7.23	8.57	86.64	165.92	7.59	8.31	86.50	166.27	14.81	16.88	173.14	332.19
Arizona	19.88	22.65	263.45	476.95	11.37	13.51	150.56	275.97	31.25	36.16	414.02	752.92
Arkansas	4.06	4.70	47.13	91.02	2.98	3.44	34.68	66.95	7.04	8.14	81.81	157.98
Colorado	11.97	13.61	148.73	277.14	12.60	14.55	155.19	291.80	24.58	28.15	303.92	568.94
Connecticut	2.88	3.64	33.06	65.92	1.85	2.24	24.20	44.87	4.73	5.88	57.26	110.78
Delaware	0.71	0.89	8.08	16.15	1.81	2.18	23.00	43.12	2.52	3.07	31.09	59.27
District of Columbia	1.28	1.60	15.12	29.63	0.58	0.70	7.45	13.91	1.86	2.31	22.57	43.55
Florida	27.74	34.52	318.72	632.13	17.04	21.74	226.23	422.46	44.78	56.26	544.95	1054.59
Georgia	12.71	16.10	145.77	290.91	10.54	12.51	145.20	261.39	23.25	28.61	290.97	552.29
Idaho	1.78	2.22	21.05	41.19	3.25	3.94	43.87	80.15	5.03	6.16	64.92	121.34
Illinois	7.64	10.04	93.35	182.59	3.71	4.78	47.85	90.89	11.35	14.82	141.20	273.48
Indiana	7.23	9.43	62.94	146.74	8.15	9.30	101.99	189.77	15.39	18.72	164.93	336.51
Iowa	2.23	2.98	26.03	52.34	2.28	2.97	28.60	55.24	4.51	5.95	54.63	107.58
Kentucky	4.14	5.10	50.59	97.15	3.22	3.88	40.14	75.95	7.36	8.98	90.73	173.11
Louisiana	4.14	5.23	47.02	94.21	4.63	5.59	53.72	105.18	8.77	10.82	100.73	199.39
Maine	1.24	1.56	14.49	28.60	1.34	1.64	16.28	31.38	2.58	3.21	30.76	59.98
Maryland	3.78	5.07	46.03	90.69	3.27	4.23	45.12	83.11	7.05	9.31	91.15	173.79
Massachusetts	2.78	3.73	32.41	65.26	2.80	3.80	33.18	66.70	5.58	7.52	65.59	131.97
Michigan	9.32	11.07	123.12	225.69	12.18	13.41	155.22	283.86	21.50	24.48	278.33	509.55
Minnesota	5.17	6.33	61.28	119.22	9.89	11.10	131.91	237.51	15.06	17.43	193.19	356.72
Mississippi	7.23	7.93	89.12	165.06	0.00	0.00	0.00	0.00	7.23	7.93	89.12	165.06
Montana	0.57	0.72	6.38	12.85	1.40	1.73	17.57	33.36	1.97	2.45	23.95	46.21
Nebraska	4.30	4.95	52.04	98.45	3.16	3.59	39.94	73.87	7.46	8.54	91.98	172.32
Nevada	5.93	7.44	68.22	135.56	4.50	5.38	60.95	110.77	10.43	12.83	129.17	246.33
New Hampshire	1.10	1.41	11.94	24.59	0.95	1.19	11.23	22.07	2.04	2.60	23.17	46.65
New Jersey	7.09	8.27	81.74	158.96	11.62	12.86	147.24	270.32	18.71	21.12	228.98	429.28
New Mexico	2.04	2.54	19.76	42.77	2.04	2.37	25.34	47.48	4.08	4.91	45.09	90.25
New York	7.26	9.41	87.98	172.15	10.26	11.75	141.35	252.18	17.52	21.16	229.32	424.33
North Carolina	9.58	12.19	108.75	218.44	12.24	14.92	163.28	300.41	21.82	27.11	272.04	518.85
Ohio	12.26	15.30	121.13	259.64	7.30	8.46	87.79	167.07	19.56	23.76	208.92	426.71
Oklahoma	5.43	6.52	61.10	121.06	8.62	9.58	110.49	201.90	14.05	16.10	171.59	322.96
Pennsylvania	8.10	10.44	88.06	181.63	5.52	6.95	65.22	128.33	13.62	17.39	153.27	309.95
Rhode Island	0.64	0.83	7.87	15.25	0.21	0.29	2.49	5.04	0.85	1.12	10.36	20.29
South Carolina	4.98	6.31	56.30	113.16	7.31	8.78	99.09	180.27	12.29	15.09	155.38	293.43
Tennessee	8.86	10.61	104.01	201.76	8.74	10.36	97.87	194.06	17.60	20.97	201.88	395.82
Texas	34.80	42.41	456.57	845.03	64.74	73.74	847.52	1544.36	99.54	116.15	1304.09	2389.39
Utah	2.40	3.24	27.88	56.33	13.08	14.26	137.51	274.58	15.48	17.50	165.38	330.91
Vermont	0.25	0.34	2.78	5.75	1.43	1.57	18.19	33.24	1.68	1.90	20.97	39.00
Virginia	9.02	11.27	106.51	208.66	10.34	12.16	143.63	257.01	19.36	23.43	250.14	465.67
West Virginia	1.75	2.05	19.90	38.96	1.06	1.23	12.54	24.01	2.81	3.27	32.44	62.97
Wisconsin	5.54	6.99	63.79	126.95	6.24	7.25	68.90	136.82	11.78	14.24	132.69	263.78
Wyoming	0.84	1.01	10.94	20.21	0.93	1.10	13.19	23.41	1.77	2.10	24.13	43.62

Table 7. Discounted Consumer Cost Savings (Billion \$ 2016)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	0.06	0.07	0.79	1.44	0.07	0.08	0.87	1.63	0.14	0.15	1.65	3.07
Arizona	0.17	0.18	2.29	4.05	0.13	0.14	1.71	3.03	0.29	0.32	4.00	7.08
Arkansas	0.03	0.03	0.32	0.61	0.03	0.03	0.30	0.57	0.05	0.06	0.63	1.18
Colorado	0.10	0.10	1.24	2.25	0.11	0.12	1.43	2.64	0.21	0.23	2.67	4.88
Connecticut	0.03	0.04	0.40	0.76	0.03	0.03	0.41	0.74	0.06	0.07	0.81	1.51
Delaware	0.01	0.01	0.07	0.14	0.02	0.02	0.27	0.50	0.03	0.03	0.34	0.63
District of Columbia	0.01	0.01	0.15	0.29	0.01	0.01	0.08	0.15	0.02	0.02	0.24	0.44
Florida	0.22	0.25	2.59	4.93	0.17	0.20	2.38	4.26	0.39	0.45	4.97	9.19
Georgia	0.10	0.12	1.23	2.36	0.11	0.12	1.54	2.69	0.21	0.24	2.77	5.05
Idaho	0.01	0.01	0.14	0.26	0.02	0.03	0.34	0.61	0.04	0.04	0.48	0.86
Illinois	0.06	0.07	0.75	1.41	0.04	0.04	0.49	0.89	0.10	0.11	1.24	2.30
Indiana	0.05	0.06	0.49	1.09	0.08	0.09	1.01	1.83	0.13	0.15	1.49	2.92
Iowa	0.02	0.02	0.19	0.36	0.02	0.02	0.28	0.52	0.04	0.04	0.47	0.88
Kentucky	0.03	0.04	0.40	0.74	0.03	0.03	0.38	0.69	0.06	0.07	0.78	1.43
Louisiana	0.03	0.04	0.37	0.71	0.04	0.04	0.46	0.88	0.07	0.08	0.83	1.59
Maine	0.01	0.01	0.15	0.29	0.02	0.02	0.27	0.51	0.03	0.04	0.43	0.80
Maryland	0.03	0.04	0.43	0.80	0.04	0.04	0.54	0.94	0.07	0.08	0.96	1.74
Massachusetts	0.03	0.04	0.39	0.75	0.04	0.05	0.54	1.01	0.07	0.09	0.92	1.76
Michigan	0.08	0.09	1.14	2.02	0.12	0.13	1.61	2.90	0.21	0.22	2.75	4.92
Minnesota	0.04	0.04	0.49	0.92	0.10	0.10	1.33	2.34	0.14	0.15	1.82	3.26
Mississippi	0.06	0.06	0.78	1.41	0.00	0.00	0.00	0.00	0.06	0.06	0.78	1.41
Montana	0.00	0.00	0.05	0.10	0.01	0.01	0.15	0.28	0.02	0.02	0.20	0.37
Nebraska	0.03	0.03	0.37	0.67	0.03	0.03	0.36	0.64	0.06	0.06	0.72	1.31
Nevada	0.04	0.05	0.54	1.02	0.05	0.05	0.67	1.19	0.09	0.11	1.21	2.21
New Hampshire	0.01	0.01	0.14	0.27	0.01	0.02	0.18	0.35	0.03	0.03	0.32	0.62
New Jersey	0.08	0.09	0.90	1.72	0.14	0.15	1.79	3.24	0.22	0.23	2.69	4.96
New Mexico	0.02	0.02	0.16	0.32	0.02	0.02	0.25	0.47	0.04	0.04	0.41	0.79
New York	0.09	0.11	1.16	2.19	0.16	0.17	2.20	3.85	0.25	0.28	3.36	6.05
North Carolina	0.07	0.08	0.78	1.50	0.12	0.13	1.65	2.94	0.19	0.21	2.43	4.44
Ohio	0.09	0.11	0.95	1.96	0.08	0.09	1.00	1.86	0.17	0.20	1.96	3.82
Oklahoma	0.04	0.04	0.43	0.82	0.08	0.09	1.07	1.93	0.12	0.13	1.50	2.75
Pennsylvania	0.07	0.08	0.76	1.51	0.07	0.08	0.83	1.58	0.14	0.16	1.59	3.09
Rhode Island	0.01	0.01	0.10	0.18	0.00	0.00	0.04	0.08	0.01	0.01	0.14	0.26
South Carolina	0.04	0.05	0.47	0.90	0.08	0.09	1.11	1.96	0.12	0.13	1.59	2.87
Tennessee	0.07	0.08	0.88	1.63	0.07	0.08	0.86	1.64	0.14	0.16	1.73	3.27
Texas	0.24	0.28	3.31	5.93	0.67	0.72	8.93	15.94	0.91	1.00	12.24	21.87
Utah	0.02	0.02	0.20	0.38	0.11	0.11	1.13	2.22	0.12	0.13	1.33	2.60
Vermont	0.00	0.00	0.03	0.06	0.02	0.02	0.31	0.55	0.03	0.03	0.34	0.61
Virginia	0.06	0.07	0.73	1.37	0.10	0.11	1.46	2.54	0.16	0.18	2.19	3.90
West Virginia	0.01	0.01	0.13	0.25	0.01	0.01	0.10	0.19	0.02	0.02	0.23	0.44
Wisconsin	0.05	0.05	0.56	1.08	0.06	0.07	0.70	1.36	0.11	0.12	1.27	2.44
Wyoming	0.01	0.01	0.08	0.15	0.01	0.01	0.12	0.21	0.01	0.02	0.20	0.35

Table 8. Avoided CO₂ Emissions (MMT)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	0.46	0.54	5.49	10.51	0.47	0.51	5.35	10.29	0.93	1.05	10.84	20.79
Arizona	1.27	1.44	16.81	30.42	0.70	0.83	9.26	17.00	1.97	2.27	26.08	47.42
Arkansas	0.26	0.30	2.98	5.76	0.18	0.21	2.13	4.12	0.44	0.51	5.12	9.88
Colorado	0.76	0.86	9.44	17.58	0.73	0.84	8.98	16.91	1.49	1.70	18.42	34.48
Connecticut	0.18	0.23	2.07	4.13	0.12	0.14	1.51	2.80	0.30	0.37	3.59	6.94
Delaware	0.04	0.06	0.51	1.02	0.11	0.13	1.43	2.67	0.16	0.19	1.93	3.69
District of Columbia	0.08	0.10	0.96	1.87	0.04	0.04	0.46	0.86	0.12	0.14	1.42	2.74
Florida	1.78	2.20	20.42	40.45	1.07	1.36	14.23	26.57	2.85	3.56	34.64	67.02
Georgia	0.81	1.02	9.27	18.47	0.66	0.78	9.05	16.30	1.46	1.80	18.33	34.78
Idaho	0.11	0.14	1.34	2.61	0.19	0.23	2.53	4.64	0.30	0.37	3.87	7.25
Illinois	0.48	0.62	5.83	11.39	0.22	0.28	2.77	5.29	0.69	0.90	8.60	16.68
Indiana	0.45	0.59	3.96	9.20	0.48	0.54	5.96	11.10	0.93	1.13	9.92	20.29
Iowa	0.14	0.19	1.63	3.27	0.14	0.18	1.71	3.30	0.28	0.36	3.34	6.58
Kentucky	0.26	0.32	3.17	6.09	0.20	0.24	2.47	4.68	0.46	0.56	5.64	10.76
Louisiana	0.26	0.33	2.99	5.99	0.29	0.35	3.33	6.52	0.55	0.68	6.32	12.51
Maine	0.08	0.10	0.90	1.78	0.08	0.10	1.02	1.96	0.16	0.20	1.92	3.74
Maryland	0.24	0.32	2.91	5.71	0.20	0.26	2.80	5.16	0.44	0.58	5.71	10.88
Massachusetts	0.17	0.23	2.03	4.08	0.18	0.24	2.07	4.17	0.35	0.47	4.11	8.26
Michigan	0.58	0.69	7.69	14.08	0.70	0.78	8.97	16.41	1.29	1.46	16.66	30.49
Minnesota	0.32	0.39	3.81	7.40	0.59	0.66	7.85	14.13	0.91	1.05	11.65	21.53
Mississippi	0.46	0.50	5.68	10.51	0.00	0.00	0.00	0.00	0.46	0.50	5.68	10.51
Montana	0.04	0.04	0.40	0.80	0.08	0.10	1.01	1.92	0.12	0.14	1.40	2.72
Nebraska	0.27	0.31	3.27	6.18	0.19	0.22	2.40	4.44	0.46	0.53	5.67	10.62
Nevada	0.38	0.47	4.35	8.63	0.27	0.32	3.65	6.64	0.65	0.79	8.00	15.27
New Hampshire	0.07	0.09	0.75	1.54	0.06	0.07	0.70	1.38	0.13	0.16	1.45	2.92
New Jersey	0.45	0.52	5.14	10.00	0.69	0.76	8.70	16.00	1.13	1.28	13.85	25.99
New Mexico	0.13	0.16	1.26	2.72	0.12	0.14	1.49	2.80	0.25	0.30	2.75	5.52
New York	0.45	0.59	5.51	10.78	0.61	0.70	8.36	14.93	1.06	1.28	13.87	25.71
North Carolina	0.61	0.77	6.90	13.85	0.76	0.93	10.16	18.70	1.37	1.70	17.06	32.55
Ohio	0.77	0.95	7.60	16.27	0.43	0.49	5.11	9.74	1.19	1.45	12.72	26.01
Oklahoma	0.34	0.41	3.87	7.66	0.53	0.59	6.78	12.39	0.87	1.00	10.65	20.05
Pennsylvania	0.51	0.65	5.53	11.39	0.33	0.41	3.84	7.58	0.83	1.06	9.37	18.97
Rhode Island	0.04	0.05	0.49	0.96	0.01	0.02	0.16	0.32	0.05	0.07	0.65	1.27
South Carolina	0.32	0.40	3.59	7.20	0.46	0.55	6.18	11.24	0.77	0.95	9.76	18.44
Tennessee	0.56	0.67	6.59	12.77	0.54	0.64	6.09	12.07	1.11	1.31	12.67	24.84
Texas	2.21	2.69	29.05	53.74	4.01	4.56	52.44	95.59	6.22	7.24	81.50	149.33
Utah	0.15	0.20	1.77	3.57	0.76	0.83	7.99	15.97	0.91	1.03	9.76	19.53
Vermont	0.02	0.02	0.17	0.36	0.09	0.10	1.14	2.08	0.11	0.12	1.31	2.43
Virginia	0.57	0.71	6.74	13.19	0.64	0.75	8.92	15.97	1.21	1.46	15.66	29.16
West Virginia	0.11	0.13	1.25	2.45	0.07	0.08	0.78	1.50	0.18	0.20	2.03	3.95
Wisconsin	0.34	0.43	3.97	7.89	0.36	0.42	3.99	7.93	0.71	0.85	7.96	15.82
Wyoming	0.05	0.06	0.69	1.27	0.05	0.06	0.76	1.35	0.11	0.13	1.45	2.62

Table 9. Annual and 5-Year Cumulative Savings

Year	Site Energy Savings (TBtu)	Primary Energy Savings (TBtu)	FFC Savings (TBtu)	Energy Cost Savings 2016 \$ (billion)	CO ₂ Reduction (MMT)
2011	3.53	8.33	8.79	0.09	0.55
2012	10.14	23.94	25.28	0.26	1.57
2013	20.13	47.42	50.07	0.50	3.11
2014	33.78	78.91	83.36	0.85	5.17
2015	54.07	124.88	132.00	1.34	8.19
Cumulative 2011-2015	121.64	283.49	299.50	3.04	18.59
2016	80.36	183.46	194.02	1.98	12.03
2017	109.32	246.21	260.55	2.65	16.13
2018	139.94	312.84	331.18	3.32	20.49
2019	159.80	354.94	375.85	3.72	23.24
2020	179.95	396.98	420.50	4.11	26.02
Cumulative 2016-2020	669.38	1494.43	1582.10	15.79	97.91
2021	200.13	439.12	465.28	4.50	28.84
2022	206.66	454.12	481.13	4.63	29.80
2023	213.32	469.05	496.92	4.76	30.76
2024	220.10	484.04	512.77	4.88	31.74
2025	225.20	495.59	524.97	4.98	32.49
Cumulative 2021-2025	1065.41	2341.93	2481.08	23.75	153.63
2026	230.43	507.26	537.31	5.07	33.25
2027	235.74	518.90	549.61	5.16	34.02
2028	240.15	528.44	559.70	5.23	34.65
2029	244.69	538.23	570.04	5.30	35.30
2030	249.36	548.24	580.63	5.37	35.96
Cumulative 2026-2030	1200.37	2641.08	2797.29	26.14	173.18
2031	253.94	558.18	591.13	5.44	36.62
2032	258.66	568.33	601.85	5.51	37.30
2033	263.56	578.82	612.93	5.57	37.99
2034	268.39	589.18	623.87	5.63	38.67
2035	273.47	600.06	635.35	5.70	39.38
Cumulative 2031-2035	1318.01	2894.57	3065.14	27.85	189.97
2036	278.77	611.45	647.38	5.76	40.12
2037	283.85	622.37	658.90	5.82	40.82
2038	289.09	633.66	670.83	5.87	41.53
2039	294.42	645.18	682.99	5.93	42.26
2040	299.48	656.11	694.53	5.98	42.93
Cumulative 2036-2040	1445.61	3168.77	3354.62	29.36	207.67

Table 10. Impact of Codes from 2010-2016

Sector	Site Energy Savings (Quads)	Primary Energy Savings (Quads)	FFC Savings (Quads)	Energy Cost Savings 2016 \$ (billion)	CO ₂ Reduction (MMT)
Commercial					
Annual 2016	0.03	0.08	0.08	0.75	5.35
Annual 2040	0.03	0.08	0.08	0.75	5.35
Cumulative 2010-2016	0.08	0.20	0.21	1.82	13.05
Cumulative 2010-2040	0.81	2.13	2.24	19.92	141.54
Residential					
Annual 2016	0.05	0.10	0.11	1.23	6.67
Annual 2040	0.05	0.10	0.11	1.23	6.67
Cumulative 2010-2016	0.13	0.27	0.29	3.20	17.57
Cumulative 2010-2040	1.32	2.74	2.91	32.71	177.73
Total					
Annual 2016	0.08	0.18	0.19	1.98	12.03
Annual 2040	0.08	0.18	0.19	1.98	12.03
Cumulative 2010-2016	0.20	0.47	0.49	5.02	30.61
Cumulative 2010-2040	2.13	4.87	5.15	52.63	319.28

Note: Annual savings in 2016 are assumed to continue accumulating each year until 2040. Savings from new construction beyond 2016 are not included in this table. Also, the following states are excluded from the analysis: AK, CA, HI, KS, MO, MS (residential only), ND, OR, SD, and WA. See section 2.1.3 for details.

4.0 References

- AIA. 2016. *The 2030 Commitment*. American Institute of Architects, Washington, D.C. Accessed at: <http://www.aia.org/practicing/2030Commitment/>
- ASHRAE. 2001. *ANSI/ASHRAE/IESNA Standard 90.1-2001, Energy Standard for Buildings Except Low-Rise Residential Buildings*. ASHRAE, Atlanta, Georgia.
- ASHRAE. 2004. *ANSI/ASHRAE/IESNA 90.1-2004, Energy Standard for Buildings Except Low-Rise Residential Buildings*. ASHRAE, Atlanta, Georgia.
- ASHRAE. 2007. *ANSI/ASHRAE/IESNA 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings*. ASHRAE, Atlanta, Georgia.
- ASHRAE. 2010. *ANSI/ASHRAE/IESNA 90.1-2010, Energy Standard for Buildings Except Low-Rise Residential Buildings*. ASHRAE, Atlanta, Georgia.
- ASHRAE. 2013. *ANSI/ASHRAE/IES Standard 90.1-2013. Energy Standard for Buildings Except Low-Rise Residential Buildings*. ASHRAE, Atlanta, Georgia.
- Bartlett, Rosemarie, M Halverson, J Goins, and P Cole. 2016. *Commercial Building Energy Code Compliance Literature Review*. PNNL-25218, Pacific Northwest National Laboratory, Richland, Washington. Available at: http://www.pnnl.gov/main/publications/external/technical_reports/PNNL-25218.pdf
- BECP. 2016a. Residential Energy Codes Field Study. Building Energy Codes Program, U.S. Department of Energy. Accessed at: www.energycodes.gov/compliance/residential-energy-code-field-study
- BECP. 2016b. Status of State Residential Energy Code Adoption as of March 2015. Building Energy Codes Program, U.S. Department of Energy. Accessed at: www.energycodes.gov/adoption/states.
- BTO. 2016. *BTO Multi-Year Program Plan*. Building Technologies Office, U.S. Department of Energy. Accessed at: <http://energy.gov/eere/buildings/downloads/multi-year-program-plan>
- Coughlin, K. *Projections of Full-Fuel-Cycle Energy and Emissions Metrics*. 2013. Lawrence Berkeley National Laboratory: Berkeley, CA. LBNL-6025E. Link: <http://eetd.lbl.gov/publications/projections-of-full-fuel-cycle-energy-and-emissions-metrics>
- BTO. 2015. *Solid-State Lighting R&D Plan*. Building Technologies Office, U.S. Department of Energy, Washington, D.C. Accessed at: http://www.energy.gov/sites/prod/files/2015/06/f22/ssl_rd-plan_may2015_0.pdf
- BTO. 2014a. *Windows and Building Envelope Research and Development: Roadmap for Emerging Technologies*. Building Technologies Office, U.S. Department of Energy, Washington, D.C. Accessed at: http://energy.gov/sites/prod/files/2014/02/f8/BTO_windows_and_envelope_report_3.pdf
- BTO. 2014b. *Research and Development Roadmap for Emerging HVAC Technologies*. Building Technologies Office, U.S. Department of Energy, Washington, D.C. Accessed at: <http://energy.gov/eere/buildings/downloads/research-development-roadmap-emerging-hvac-technologies>

BTO. 2014c. *Research and Development Roadmap for Emerging Water Heating Technologies*. Building Technologies Office, U.S. Department of Energy, Washington, D.C. Accessed at: <http://energy.gov/eere/buildings/downloads/research-development-roadmap-emerging-water-heating-technologies>

EIA. 2015. *Annual Energy Outlook 2015*. U.S. Energy Information Administration. Accessed at <http://www.eia.doe.gov/forecasts/aeo/>

EIA. 2016a. *EIA 826 Electricity Data*. Energy Information Administration, Washington, D.C. Last accessed on 07/13/2016 at: <https://www.eia.gov/electricity/data/eia826/>

EIA. 2016b. *Natural gas prices*. Energy Information Administration, Washington, D.C. Last accessed on 07/13/2016 at: <http://www.eia.gov/naturalgas/data.cfm>

EIA. 2016c. *State Energy Data System*. Energy Information Administration, Washington, D.C. Last accessed on 07/13/2016 at: <http://www.eia.gov/state/seds/>

EPA. 2016. ENERGY STAR. U.S. Environmental Protection Agency and U.S. Department of Energy, Washington, D.C. Available at: www.energystar.gov

Halverson M. A., R. A. Athalye, M. I. Rosenberg, Y. L. Xie, W. Wang, P. R. Hart, J. Zhang, S. Goel, and V. V. Mendon. 2014. *ANSI/ASHRAE/IES Standard 90.1-2013 Determination of Energy Savings: Quantitative Analysis*. PNNL-23479, Pacific Northwest National Laboratory, Richland, WA.

ICC. 2003. *2003 International Energy Conservation Code®*. International Code Council, Washington D.C.

ICC. 2006. *2006 International Energy Conservation Code®*. International Code Council, Washington D.C.

ICC. 2009. *2009 International Energy Conservation Code®*. International Code Council, Washington D.C.

ICC. 2012. *2012 International Energy Conservation Code®*. International Code Council, Washington D.C.

ICC. 2015. *2015 International Energy Conservation Code®*. International Code Council, Washington D.C.

Livingston, Olga, D Elliott, P Cole, and R Bartlett. 2014. *Building Energy Codes Program: National Benefits Assessment, 1992-2040*. PNNL-22610, Pacific Northwest National Laboratory, Richland, Washington.

Mendon, Vrushali, Z Taylor, S Rao, and Y Xie. 2015. *2015 IECC: Energy Savings Analysis*. PNNL-23977, Pacific Northwest National Laboratory, Richland, Washington.

Mendon, Vrushali, M Zhao, Z Taylor, and E Poehlman. 2016. *2015 IECC State Cost-effectiveness Analysis–51 state reports*. Pacific Northwest National Laboratory, Richland, Washington. Available at: https://www.energycodes.gov/development/residential/iecc_analysis

Lucas, Robert, V Mendon, and S Goel. 2013. *Energy Use Savings for a Typical New Residential Dwelling Unit Based on the 2009 and 2012 IECC as Compared to the 2006 IECC*. PNNL-88603. Pacific Northwest National Laboratory, Richland, Washington. Available at: <https://www.energycodes.gov/sites/default/files/documents/NationalResidentialEnergyAnalysis.pdf>

Rosenberg, Michael, R Hart, R Athalye, J Zhang, W Wang, B Liu. 2016. *An Approach to Assessing Potential Energy Cost Savings from Increased Energy Code Compliance in Commercial Buildings*. Pacific Northwest National Laboratory, Richland, Washington. Available at: http://www.pnnl.gov/main/publications/external/technical_reports/PNNL-24979.pdf.

USGBC. 2016. *Leadership in Energy and Environmental Design*. U.S. Green Building Council, Washington, D.C. Available at: www.usgbc.org/leed

Appendix A
Model Inputs

Appendix A

Model Inputs

This appendix provides detailed information on the inputs used for adoption, code-to-code savings, floor space, and in the conversion of savings to different energy and environmental units that are used in the codes impact methodology described in section 2.0.

A.1 Adoption

Table A.1 and Table A.2 show the year in which various code editions were adopted by each state, as well as the future rate of adoption (timely, medium slow, or slow) for each state for commercial and residential codes, respectively. The adoption year for code editions up to the 2018 IECC (and 90.1-2016) are shown, but adoption years for future code editions can be calculated by adding the adoption time lag of the state to the year of the published code. In terms of older codes, only 90.1-2001 is shown for commercial and 2003 IECC for residential because all states in the analysis had adopted these codes by 2010—the starting point for the analysis—and thus, there is no need to assess codes older than 90.1-2001 and 2003 IECC.

Table A.1. Commercial Codes Adoption Classification by State

State	Adoption Classification	Adoption Lag Years	IECC												
			2000/2003	90.1-1999/2001	IECC 2006	IECC 2009	IECC 2012	IECC 2015	IECC 2018	IECC 2021	IECC 2024	IECC 2027	IECC 2030	IECC 2033	IECC 2036
Code Year			2000	2006	2009	2012	2015	2018	2021	2024	2027	2030	2033	2036	2039
Alabama	Very Slow	7	2010	2013	2013	2016	2016	2025	2028	2031	2034	2037	2040	2043	2046
Alaska	NA														
Arizona	Medium Slow	4	2010	2013	2013	2013	2019	2022	2025	2028	2031	2034	2037	2040	2043
Arkansas	Very Slow	7	2005	2013	2013	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
California	NA														
Colorado	Medium Slow	4	2007	2012	2012	2017	2017	2022	2025	2028	2031	2034	2037	2040	2043
Connecticut	Medium Slow	4	2005	2009	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Delaware	Medium Slow	4	2004	2010	2010	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
District of Columbia	Medium Slow	4	2004	2010	2010	2014	2019	2022	2025	2028	2031	2034	2037	2040	2043
Florida	Medium Slow	4	2005	2007	2012	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Georgia	Medium Slow	4	2003	2008	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Hawaii	NA														
Idaho	Medium Slow	4	2005	2008	2011	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Illinois	Timely	1	2006	2008	2010	2013	2016	2019	2022	2025	2028	2031	2034	2037	2040
Indiana	Very Slow	7	2010	2010	2010	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Iowa	Timely	1	2004	2007	2010	2014	2016	2019	2022	2025	2028	2031	2034	2037	2040
Kansas	NA														
Kentucky	Medium Slow	4	2005	2007	2011	2014	2019	2022	2025	2028	2031	2034	2037	2040	2043
Louisiana	Medium Slow	4	2005	2007	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Maine	Medium Slow	4	2000	2005	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Maryland	Timely	1	2005	2007	2010	2012	2015	2019	2022	2025	2028	2031	2034	2037	2040
Massachusetts	Timely	1	2001	2008	2010	2014	2016	2019	2022	2025	2028	2031	2034	2037	2040
Michigan	Medium Slow	4	2009	2011	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Minnesota	Medium Slow	4	2009	2009	2015	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Mississippi	Very Slow	7	2010	2013	2013	2013	2022	2025	2028	2031	2034	2037	2040	2043	2046
Missouri	NA														
Montana	Medium Slow	4	2005	2010	2010	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Nebraska	Very Slow	7	2005	2012	2012	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Nevada	Medium Slow	4	2005	2010	2012	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
New Hampshire	Medium Slow	4	2002	2007	2010	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043

Table A.1. (contd)

State	Adoption Classification	Adoption Lag Years	IECC												
			2000/2003 90.1-1999/ 2001	2006 90.1- 2004	2009 90.1- 2007	2012 90.1- 2010	2015 90.1- 2013	2018 90.1- 2016	2021 90.1- 2019	2024 90.1- 2022	2027 90.1- 2025	2030 90.1- 2028	2033 90.1- 2031	2036 90.1- 2034	2039 90.1- 2037
New Jersey	Medium Slow	4	2002	2007	2011	2016	2016	2022	2025	2028	2031	2034	2037	2040	2043
New Mexico	Very Slow	7	2004	2008	2012	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
New York	Timely	1	2002	2008	2011	2015	2017	2019	2022	2025	2028	2031	2034	2037	2040
North Carolina	Medium Slow	4	2006	2009	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
North Dakota	NA														
Ohio	Very Slow	7	2005	2008	2012	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Oklahoma	Very Slow	7	2010	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Oregon	NA														
Pennsylvania	Medium Slow	4	2004	2007	2010	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Rhode Island	Timely	1	2004	2007	2010	2013	2016	2019	2022	2025	2028	2031	2034	2037	2040
South Carolina	Medium Slow	4	2005	2008	2013	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
South Dakota	NA														
Tennessee	Very Slow	7	2010	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Texas	Medium Slow	4	2001	2011	2011	2016	2017	2022	2025	2028	2031	2034	2037	2040	2043
Utah	Timely	1	2002	2007	2010	2014	2016	2019	2022	2025	2028	2031	2034	2037	2040
Vermont	Medium Slow	4	2001	2007	2012	2015	2015	2022	2025	2028	2031	2034	2037	2040	2043
Virginia	Medium Slow	4	2004	2006	2011	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Washington	NA														
West Virginia	Very Slow	7	2010	2014	2014	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Wisconsin	Medium Slow	4	2008	2008	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Wyoming	Medium Slow	4	2010	2011	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043

A.3

Table A.2. Residential Codes Adoption Classification by State

State	Adoption Classification	Adoption Lag Years	IECC 2003	IECC 2006	IECC 2009	IECC 2012	IECC 2015	IECC 2018	IECC 2021	IECC 2024	IECC 2027	IECC 2030	IECC 2033	IECC 2036	IECC 2039
Code Year			2003	2006	2009	2012	2015	2018	2021	2024	2027	2030	2033	2036	2039
Alabama	Very Slow	7	2010	2013	2013	2016	2016	2025	2028	2031	2034	2037	2040	2043	2046
Alaska	NA														
Arizona	Medium Slow	4	2010	2013	2013	2013	2019	2022	2025	2028	2031	2034	2037	2040	2043
Arkansas	Very Slow	7	2005	2013	2013	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
California	NA														
Colorado	Medium Slow	4	2007	2012	2012	2017	2017	2022	2025	2028	2031	2034	2037	2040	2043
Connecticut	Medium Slow	4	2005	2009	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Delaware	Medium Slow	4	2004	2010	2010	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
District of Columbia	Medium Slow	4	2004	2010	2010	2014	2019	2022	2025	2028	2031	2034	2037	2040	2043
Florida	Medium Slow	4	2005	2007	2012	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Georgia	Medium Slow	4	2003	2008	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Hawaii	NA														
Idaho	Medium Slow	4	2005	2008	2011	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Illinois	Timely	1	2006	2008	2010	2013	2016	2019	2022	2025	2028	2031	2034	2037	2040
Indiana	Very Slow	7	2010	2010	2010	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Iowa	Timely	1	2004	2007	2010	2014	2016	2019	2022	2025	2028	2031	2034	2037	2040
Kansas	NA														
Kentucky	Medium Slow	4	2005	2007	2011	2014	2019	2022	2025	2028	2031	2034	2037	2040	2043
Louisiana	Very Slow	7	2005	2007	2012	2016	2019	2022	2028	2031	2034	2037	2040	2043	2046
Maine	Medium Slow	4	2000	2005	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Maryland	Timely	1	2005	2007	2010	2012	2015	2019	2022	2025	2028	2031	2034	2037	2040
Massachusetts	Timely	1	2001	2008	2010	2014	2016	2019	2022	2025	2028	2031	2034	2037	2040
Michigan	Medium Slow	4	2009	2011	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Minnesota	Medium Slow	4	2009	2009	2015	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Mississippi	NA														
Missouri	NA														
Montana	Medium Slow	4	2005	2010	2010	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Nebraska	Very Slow	7	2005	2012	2012	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Nevada	Medium Slow	4	2005	2010	2012	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
New Hampshire	Medium Slow	4	2002	2007	2010	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
New Jersey	Medium Slow	4	2002	2007	2011	2016	2016	2022	2025	2028	2031	2034	2037	2040	2043
New Mexico	Very Slow	7	2004	2008	2012	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046

Table A.2. (contd)

State	Adoption Classification	Adoption Lag Years	IECC 2003	IECC 2006	IECC 2009	IECC 2012	IECC 2015	IECC 2018	IECC 2021	IECC 2024	IECC 2027	IECC 2030	IECC 2033	IECC 2036	IECC 2039
New York	Timely	1	2002	2008	2011	2015	2017	2019	2022	2025	2028	2031	2034	2037	2040
North Carolina	Medium Slow	4	2006	2009	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
North Dakota	NA														
Ohio	Very Slow	7	2005	2008	2012	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Oklahoma	Very Slow	7	2010	2012	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Oregon	NA														
Pennsylvania	Medium Slow	4	2004	2007	2010	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
Rhode Island	Timely	1	2004	2007	2010	2013	2016	2019	2022	2025	2028	2031	2034	2037	2040
South Carolina	Medium Slow	4	2005	2008	2013	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043
South Dakota	NA														
Tennessee	Very Slow	7	2010	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Texas	Medium Slow	4	2001	2011	2011	2016	2017	2022	2025	2028	2031	2034	2037	2040	2043
Utah	Very Slow	7	2002	2007	2010	2014	2016	2019	2028	2031	2034	2037	2040	2043	2046
Vermont	Medium Slow	4	2001	2007	2012	2015	2015	2022	2025	2028	2031	2034	2037	2040	2043
Virginia	Medium Slow	4	2004	2006	2011	2015	2019	2022	2025	2028	2031	2034	2037	2040	2043
Washington	NA														
West Virginia	Very Slow	7	2010	2014	2014	2019	2022	2025	2028	2031	2034	2037	2040	2043	2046
Wisconsin	Very Slow	7	2008	2008	2012	2016	2019	2022	2028	2031	2034	2037	2040	2043	2046
Wyoming	Medium Slow	4	2010	2011	2011	2016	2019	2022	2025	2028	2031	2034	2037	2040	2043

A.2 Code-to-Code-Savings

As described in section 2.1.4, code-to-code savings are calculated by using the Determination process. Previous Determinations issued by DOE and the supporting quantitative analysis reports can be found on the BECP website¹. These reports include detailed information on EUIs for four commercial and residential code editions: 2004, 2007, 2010, and 2013 editions of 90.1 for commercial, and 2006, 2009, 2012, 2015 editions of the IECC for residential. For codes older than 90.1-2004 and 2006 IECC, the historical EUI index developed by PNNL is used. This index is anchored with a value of 1.0 for the EUI of 90.1-2004 for commercial and 2006 IECC for residential. Going back one edition of codes (because one cycle is all that is needed for this analysis), the EUI index for 90.1-2001 (ASHRAE 2001) is 1.141, and for 2003 IECC (ICC 2003) is 1.012.

Future code EUIs are developed based off the EUI of 90.1-2013 for commercial and 2015 IECC for residential. For future commercial code editions, plug and process loads are not affected. Similarly, the DHW consumption for residential buildings is not affected by code improvements in the future. Energy reduction factors are developed for future code editions as explained in section 2.1.4. These factors are shown in Table A.3 for commercial and Table A.4 for residential. The following steps are taken to develop the energy reduction factors:

1. Start by applying a reduction factor by end-use based on technological progress from BTO's technology roadmap reports (BTO 2015, 2014, a,b,c).
2. The energy reduction factors for 90.1-2016 are adjusted based on known savings from PNNL's internal analysis (not published as of August 2016). For residential, no such adjustment is made to 2018 IECC.
3. Finally, the remaining code editions are readjusted based on the changes made to 90.1-2016. No changes are necessary for residential energy reduction factors.

The technological progress is not constant through time. For example, lighting savings in the BTO reports are projected to increase less rapidly up to 2030 and more rapidly beyond 2030. This, and the adjustment to 90.1-2016, is built into the energy reduction factors, and therefore, they are not linear over the period from 2016-2040. The factors vary for different end-uses and depend upon the future potential for improvement for the end-use category. The envelope technology improvements are reflected in the HVAC end-use category. Equipment efficiency improvements are not included in the future projections.

Table A.3. Commercial Future Code Edition Energy Reduction Factors (90.1-2013 = 1.00)

End-Use	IECC 2018 90.1-2016	IECC 2021 90.1-2019	IECC 2024 90.1-2022	IECC 2027 90.1-2025	IECC 2030 90.1-2028	IECC 2033 90.1-2031	IECC 2036 90.1-2034	IECC 2039 90.1-2037
Electricity – HVAC	0.90	0.80	0.74	0.68	0.62	0.56	0.50	0.44
Electricity – Lighting	0.92	0.86	0.80	0.72	0.64	0.56	0.48	0.40
NG – HVAC	0.90	0.80	0.74	0.68	0.62	0.56	0.50	0.44
NG – Plug and Process	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Electricity – Plug and Process	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

¹ Determinations on BECP website: <https://www.energycodes.gov/determinations>

Table A.4. Residential Future Code Edition Energy Reduction Factors (2015 IECC = 1.00)

End-Use	IECC 2018	IECC 2021	IECC 2024	IECC 2027	IECC 2030	IECC 2033	IECC 2036	IECC 2039
Electricity – HVAC	0.95	0.90	0.85	0.80	0.75	0.70	0.65	0.60
Electricity – Lighting	0.96	0.92	0.88	0.80	0.72	0.64	0.56	0.48
Electricity DHW	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
NG – HVAC	0.95	0.90	0.85	0.80	0.75	0.70	0.65	0.60
NG – DHW	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Oil – HVAC	0.95	0.90	0.85	0.80	0.75	0.70	0.65	0.60
Oil – DHW	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

Table A.5 shows the relative improvement in each future code edition as a percentage reduction in energy consumption of the previous edition given the energy reduction factors established in Table A.3 and Table A.4. These overall code-to-code savings are calculated by first weighting the state-level results up to the national level and then comparing the national weighted EUIs. Future code editions have a smaller impact on both the annual and cumulative savings calculated in this analysis because the savings have less time to add up.

Table A.5. Future Code Edition Savings

Commercial		Residential	
Code Edition	% Savings Compared to Previous Code	Code Edition	% Savings Compared to Previous Code
90.1-2016	5	2018 IECC	4
90.1-2019	5	2021 IECC	4
90.1-2022	4	2024 IECC	4
90.1-2025	4	2027 IECC	4
90.1-2028	5	2030 IECC	5
90.1-2031	5	2033 IECC	5
90.1-2034	5	2026 IECC	5
90.1-2037	5	2039 IECC	5

A.3 Floor Space

As described in section 2.1.6, new floor space added from 1992 to 2040 calculated in a previous analysis (Livingston et al. 2014) is used in this analysis. The previous analysis used data from AEO 2012. Since the publication of the previous analysis, new data has become available from EIA and this data is used to update new floor space added each year. This and other updates are described in detail here.

Commercial floor space updates. For the commercial forecast, the underlying source of floor space forecasts is updated from AEO 2012 to AEO 2015 (EIA 2015). Data from AEO 2015 is also used to update scaling factors that are used to realistically meld the historical floor space data with the AEO data. Specifically, scaling factors that were forecasted for the years 2011 through 2015 in the previous analysis are adjusted in order to provide a more realistic transition from the depressed construction levels of 2010. Factors from the previous analysis and the ones calculated for the current analysis are shown in Table A.6.

Table A.6. Commercial Floor Space Scaling Factors 2011-2014

Year	Scaling Factors from	
	Livingston et al. 2014	New Scaling Factors
2011	0.6306	0.6328
2012	0.6203	0.6172
2013	0.7544	0.7412
2014	0.9011	0.8320

Residential floor space updates. Residential floor space estimates are based on households, and again the underlying AEO data from 2012 is updated using newer data from AEO 2015. Other changes are made to the residential household estimates and are described below.

1. In the prior analysis, Census Bureau residential building permit data, for the years 1991 through 2012, were used to develop a time-series of historical floor space estimates. This time series is extended through 2014 in the current analysis.
2. The fraction of multi-family units classified as low-rise is estimated using 2005-2014 Census Bureau building permit data in this analysis, whereas in the prior analysis, data from the years 2003-2012 were utilized. This multi-family fraction is applied to AEO-derived multi-family household data to extract an estimate of low-rise multi-family households added each year.
3. As in the previous analysis, annual residential stock survival factors from EIA's National Energy Modeling System (NEMS) residential documentation are applied to the stock to derive a forecast of additions to residential stock. However, the factors changed slightly as shown in Table A.7.

Table A.7. Residential Stock Survival Factors

Type of Building Stock	Stock Survival Factors from	
	Livingston et al. 2014	New Stock Survival Factor
Single-family	0.996	0.997
Multi-family	0.999	0.995
Mobile home	0.976	0.966

4. A correction to the size of the prototype single-family home is applied, reducing the size to 2,376 square feet from the prior 2,400 square feet. This updated value is obtained from the Methodology for Evaluating Cost-Effectiveness of Residential Energy Code Changes (Taylor et al. 2015).
5. Regarding the integration of historical and projected data (discussed in section 4.2.3 of the previous report), the Census data are at the state level, and provide data for the years 1992 through 2014. The AEO data are at the Census Division level, and include data for the years 2009 through 2040. These two data series, which reasonably closely match for overlapping years, are melded to provide a Census Division-level series. In order to generate state-level time-series data through 2040, growth rates inferred from the melded Census Division-level time series are applied to the 2014 state-level Census data. An implicit assumption is that state shares within each Census Division remain constant at 2014 levels.

A.4 Savings Conversions

Energy Prices. Energy prices are used for computing consumer cost savings by applying prices to the site energy savings. Prices for electricity, natural gas, and fuel oil are derived from EIA databases such as EIA 826, Natural Gas Navigator, and State Energy Data System (EIA 2016a,b,c). Once energy prices are obtained from these databases, the actual forecast indices calculated from AEO price data are applied to each fuel price to derive the future stream of annual prices for each fuel. Prices are expressed in real dollars. Subsequently, the energy savings in each year are used in conjunction with relevant fuel prices to estimate the financial benefits accrued with time. A discounted cash flow framework with a real discount rate of 5% is then used to discount the future stream of benefits back to year 2016 monetary values. A discount rate of 5% is chosen as an average between 3% and 7%, which are the boundary values used in various federal rulemaking analyses at PNNL.

Environmental Conversion Factors. Coughlin describes a method and provides a generic framework to calculate utility sector impacts (Coughlin 2013). This framework is used in the analysis. Conversion factors are obtained from NEMS through the National Impact Analysis Plus (NIAplus) model. This module consists of annual time series of different factors (MMBtu/kWh, or kg emissions/kWh) that allow conversion of site energy savings to different energy and environmental units.

Appendix B

Site Energy Savings By Fuel Type

Table B.1. Electricity Site Energy Savings by State (TBtu)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	2.11	2.57	24.79	48.29	1.99	2.24	22.59	43.82	4.10	4.80	47.38	92.11
Arizona	5.94	0.67	77.88	142.47	2.90	3.60	37.42	70.24	8.83	4.27	115.30	212.71
Arkansas	1.15	0.38	13.17	25.82	0.71	0.85	8.22	16.11	1.87	1.24	21.39	41.93
Colorado	3.37	1.17	41.60	78.07	1.63	2.08	19.51	38.23	5.00	3.25	61.11	116.30
Connecticut	0.77	0.46	8.77	17.78	0.19	0.26	2.27	4.57	0.96	0.73	11.04	22.35
Delaware	0.20	0.09	2.20	4.48	0.49	0.61	6.06	11.59	0.68	0.70	8.26	16.07
District of Columbia	0.37	0.11	4.31	8.58	0.15	0.20	1.94	3.72	0.52	0.31	6.25	12.29
Florida	8.55	0.54	96.62	194.98	5.12	6.80	66.54	126.92	13.66	7.34	163.16	321.90
Georgia	3.74	0.91	42.34	85.86	2.94	3.62	39.94	73.03	6.68	4.53	82.28	158.89
Idaho	0.51	0.19	5.99	11.82	0.43	0.59	5.46	10.65	0.94	0.78	11.45	22.47
Illinois	2.00	1.49	24.10	48.02	0.54	0.78	6.20	12.98	2.55	2.28	30.31	61.00
Indiana	1.96	1.34	16.83	39.86	1.17	1.43	14.48	27.58	3.13	2.77	31.32	67.45
Iowa	0.60	0.40	6.88	14.10	0.45	0.63	5.34	10.88	1.05	1.03	12.22	24.98
Kentucky	1.11	0.64	13.32	26.06	0.82	1.03	10.00	19.37	1.93	1.67	23.33	45.43
Louisiana	1.23	0.25	13.75	28.05	1.19	1.50	13.72	27.30	2.42	1.75	27.48	55.35
Maine	0.31	0.26	3.61	7.27	0.11	0.16	1.22	2.63	0.43	0.42	4.83	9.90
Maryland	1.07	0.47	12.80	25.71	0.90	1.22	11.99	22.76	1.97	1.70	24.79	48.47
Massachusetts	0.75	0.49	8.61	17.64	0.31	0.50	2.99	7.13	1.06	0.99	11.60	24.78
Michigan	2.40	1.68	31.42	58.31	1.50	1.75	18.84	35.21	3.90	3.42	50.25	93.52
Minnesota	1.29	1.12	15.10	29.85	1.81	2.11	23.69	43.44	3.10	3.23	38.79	73.29
Mississippi	2.10	0.46	25.57	47.76	0.00	0.00	0.00	0.00	2.10	0.46	25.57	47.76
Montana	0.15	0.11	1.63	3.35	0.16	0.23	1.91	3.93	0.31	0.34	3.54	7.28
Nebraska	1.16	0.62	13.78	26.39	0.61	0.73	7.71	14.48	1.77	1.35	21.49	40.86
Nevada	1.78	0.31	20.21	40.75	0.90	1.16	11.73	22.17	2.68	1.48	31.95	62.92
New Hampshire	0.29	0.20	3.12	6.55	0.09	0.13	0.92	2.05	0.38	0.33	4.04	8.60
New Jersey	1.89	1.06	21.55	42.43	1.66	1.96	20.57	38.81	3.55	3.02	42.12	81.24
New Mexico	0.61	0.14	5.87	12.88	0.33	0.42	4.02	7.78	0.94	0.56	9.90	20.66
New York	1.96	1.18	23.22	46.44	1.53	1.86	20.29	37.41	3.48	3.04	43.50	83.85
North Carolina	2.80	0.76	31.28	63.97	3.37	4.29	44.18	82.94	6.17	5.05	75.46	146.91
Ohio	3.31	2.05	32.02	70.03	1.00	1.26	11.89	23.31	4.31	3.31	43.90	93.34
Oklahoma	1.55	0.56	17.13	34.49	2.03	2.32	25.95	47.79	3.58	2.88	43.07	82.28
Pennsylvania	2.20	1.29	23.60	49.53	0.81	1.14	8.93	18.90	3.01	2.43	32.53	68.42
Rhode Island	0.17	0.11	2.10	4.13	0.02	0.04	0.23	0.56	0.20	0.14	2.33	4.69
South Carolina	1.49	0.29	16.57	33.85	2.04	2.55	27.18	50.37	3.53	2.84	43.76	84.22
Tennessee	2.53	0.87	29.10	57.43	2.29	2.82	25.21	50.98	4.82	3.69	54.31	108.41
Texas	10.30	1.98	132.72	249.66	16.58	19.53	215.65	397.59	26.88	21.50	348.36	647.25
Utah	0.70	0.26	8.09	16.49	1.87	2.17	19.09	39.32	2.56	2.42	27.18	55.81
Vermont	0.07	0.05	0.71	1.50	0.11	0.13	1.37	2.61	0.18	0.19	2.08	4.11
Virginia	2.58	0.86	29.90	59.69	2.81	3.43	38.37	69.85	5.39	4.29	68.27	129.54
West Virginia	0.48	0.25	5.30	10.54	0.29	0.35	3.39	6.58	0.76	0.59	8.69	17.12
Wisconsin	1.40	1.19	15.91	32.25	0.79	0.99	8.55	17.56	2.20	2.18	24.46	49.82
Wyoming	0.23	0.12	2.91	5.45	0.12	0.15	1.61	2.97	0.34	0.27	4.52	8.42

B.1

Table B.2. Natural Gas Site Energy Savings by State (TBtu)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	0.43	0.51	5.41	10.11	1.07	1.12	11.75	22.74	1.50	1.63	17.16	32.85
Arizona	0.59	0.67	7.83	14.14	1.77	1.94	24.56	43.17	2.35	2.61	32.39	57.31
Arkansas	0.33	0.38	3.94	7.50	0.60	0.66	6.96	13.30	0.93	1.04	10.89	20.80
Colorado	0.96	1.17	11.75	22.47	6.54	7.18	81.35	150.23	7.51	8.34	93.11	172.71
Connecticut	0.36	0.46	4.10	8.26	0.71	0.81	9.50	17.12	1.07	1.27	13.60	25.38
Delaware	0.07	0.09	0.84	1.68	0.21	0.24	2.75	5.01	0.28	0.33	3.59	6.69
District of Columbia	0.09	0.11	1.01	2.02	0.07	0.08	0.95	1.70	0.16	0.19	1.96	3.72
Florida	0.41	0.54	4.67	9.46	0.52	0.59	7.20	12.81	0.93	1.13	11.87	22.28
Georgia	0.67	0.91	7.44	15.45	0.89	0.99	12.32	21.76	1.56	1.90	19.76	37.21
Idaho	0.13	0.19	1.39	3.02	1.66	1.88	23.14	40.95	1.79	2.07	24.54	43.97
Illinois	1.13	1.49	13.41	26.62	1.76	2.13	24.55	44.19	2.89	3.62	37.96	70.81
Indiana	1.01	1.34	8.45	20.31	3.87	4.25	48.34	89.14	4.88	5.59	56.79	109.45
Iowa	0.29	0.40	3.31	6.80	0.74	0.92	9.93	18.33	1.04	1.32	13.24	25.13
Kentucky	0.52	0.64	6.47	12.29	0.50	0.58	6.53	11.97	1.03	1.21	12.99	24.25
Louisiana	0.19	0.25	2.15	4.37	0.69	0.80	7.86	15.39	0.89	1.05	10.01	19.76
Maine	0.21	0.26	2.46	4.84	0.56	0.65	6.95	13.01	0.77	0.91	9.41	17.84
Maryland	0.34	0.47	3.99	8.10	0.35	0.42	5.23	9.09	0.69	0.89	9.22	17.19
Massachusetts	0.36	0.49	4.01	8.32	1.03	1.30	13.29	25.08	1.39	1.79	17.30	33.40
Michigan	1.41	1.68	18.38	33.89	6.49	6.97	82.87	150.43	7.89	8.65	101.26	184.32
Minnesota	0.92	1.12	10.85	21.13	3.54	3.89	47.85	85.18	4.46	5.01	58.70	106.31
Mississippi	0.42	0.46	5.20	9.62	0.00	0.00	0.00	0.00	0.42	0.46	5.20	9.62
Montana	0.09	0.11	0.97	1.95	0.78	0.90	10.08	18.52	0.86	1.01	11.05	20.48
Nebraska	0.54	0.62	6.49	12.31	1.03	1.14	12.99	23.89	1.57	1.76	19.49	36.19
Nevada	0.23	0.31	2.34	5.07	1.42	1.56	19.99	34.93	1.65	1.87	22.32	40.00
New Hampshire	0.15	0.20	1.62	3.40	0.38	0.44	4.67	8.82	0.53	0.64	6.29	12.21
New Jersey	0.91	1.06	10.48	20.38	5.19	5.54	66.35	120.17	6.09	6.60	76.84	140.55
New Mexico	0.10	0.14	0.88	2.09	0.87	0.95	10.82	19.91	0.96	1.09	11.69	21.99
New York	0.91	1.18	11.19	21.76	4.42	4.88	62.08	108.83	5.33	6.06	73.27	130.58
North Carolina	0.58	0.76	6.50	13.23	1.18	1.33	16.18	28.83	1.76	2.09	22.68	42.06
Ohio	1.65	2.05	16.52	35.18	3.60	3.99	43.33	81.50	5.25	6.05	59.85	116.68
Oklahoma	0.45	0.56	5.16	10.23	1.80	1.95	22.62	41.45	2.25	2.51	27.78	51.68
Pennsylvania	0.99	1.29	10.37	21.86	2.43	2.87	30.08	56.80	3.42	4.15	40.45	78.65
Rhode Island	0.08	0.11	0.92	1.86	0.08	0.10	0.98	1.86	0.15	0.20	1.90	3.71
South Carolina	0.21	0.29	2.25	4.80	0.62	0.69	8.66	15.24	0.83	0.98	10.91	20.04
Tennessee	0.73	0.87	8.80	16.86	1.22	1.35	13.92	26.87	1.96	2.22	22.72	43.74
Texas	1.59	1.98	21.70	39.65	9.79	10.59	125.12	227.43	11.38	12.57	146.82	267.08
Utah	0.16	0.26	1.43	3.54	6.35	6.67	67.56	132.77	6.51	6.92	68.99	136.31
Vermont	0.04	0.05	0.44	0.91	0.61	0.65	7.77	14.06	0.65	0.70	8.21	14.97
Virginia	0.69	0.86	8.37	16.21	1.08	1.19	15.47	26.87	1.77	2.05	23.83	43.08
West Virginia	0.21	0.25	2.43	4.73	0.11	0.12	1.28	2.43	0.32	0.37	3.71	7.16
Wisconsin	0.95	1.19	10.85	21.61	3.27	3.67	36.34	71.26	4.21	4.86	47.18	92.87
Wyoming	0.10	0.12	1.30	2.40	0.49	0.55	7.04	12.30	0.59	0.67	8.34	14.70

Table B.3. Fuel Oil Site Energy Savings by State (TBTu)

State	Commercial				Residential				Total			
	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040	Annual 2030	Annual 2040	Cumulative 2010-2030	Cumulative 2010-2040
Alabama	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Arizona	0.00	0.00	0.00	0.00	0.00	0.00	0.06	0.11	0.00	0.00	0.06	0.11
Arkansas	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Colorado	0.00	0.00	0.00	0.00	0.02	0.02	0.20	0.38	0.02	0.02	0.20	0.38
Connecticut	0.00	0.00	0.00	0.00	0.39	0.45	5.25	9.50	0.39	0.45	5.25	9.50
Delaware	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.03	0.00	0.00	0.01	0.03
District of Columbia	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.01
Florida	0.00	0.00	0.00	0.00	0.00	0.00	0.04	0.07	0.00	0.00	0.04	0.07
Georgia	0.00	0.00	0.00	0.00	0.00	0.01	0.06	0.11	0.00	0.01	0.06	0.11
Idaho	0.00	0.00	0.00	0.00	0.00	0.00	0.06	0.10	0.00	0.00	0.06	0.10
Illinois	0.00	0.00	0.00	0.00	0.01	0.01	0.15	0.27	0.01	0.01	0.15	0.27
Indiana	0.00	0.00	0.00	0.00	0.02	0.03	0.30	0.56	0.02	0.03	0.30	0.56
Iowa	0.00	0.00	0.00	0.00	0.00	0.01	0.06	0.11	0.00	0.01	0.06	0.11
Kentucky	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Louisiana	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Maine	0.00	0.00	0.00	0.00	0.31	0.36	3.85	7.23	0.31	0.36	3.85	7.23
Maryland	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.05	0.00	0.00	0.03	0.05
Massachusetts	0.00	0.00	0.00	0.00	0.58	0.73	7.40	14.04	0.58	0.73	7.40	14.04
Michigan	0.00	0.00	0.00	0.00	0.04	0.05	0.54	0.98	0.04	0.05	0.54	0.98
Minnesota	0.00	0.00	0.00	0.00	0.02	0.02	0.28	0.51	0.02	0.02	0.28	0.51
Mississippi	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Montana	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.05	0.00	0.00	0.02	0.05
Nebraska	0.00	0.00	0.00	0.00	0.01	0.01	0.08	0.16	0.01	0.01	0.08	0.16
Nevada	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.09	0.00	0.00	0.05	0.09
New Hampshire	0.00	0.00	0.00	0.00	0.21	0.25	2.58	4.89	0.21	0.25	2.58	4.89
New Jersey	0.00	0.00	0.00	0.00	0.37	0.40	4.69	8.53	0.37	0.40	4.69	8.53
New Mexico	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.05	0.00	0.00	0.03	0.05
New York	0.00	0.00	0.00	0.00	0.32	0.35	4.44	7.81	0.32	0.35	4.44	7.81
North Carolina	0.00	0.00	0.00	0.00	0.01	0.01	0.08	0.14	0.01	0.01	0.08	0.14
Ohio	0.00	0.00	0.00	0.00	0.02	0.03	0.28	0.52	0.02	0.03	0.28	0.52
Oklahoma	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Pennsylvania	0.00	0.00	0.00	0.00	0.17	0.20	2.06	3.90	0.17	0.20	2.06	3.90
Rhode Island	0.00	0.00	0.00	0.00	0.04	0.05	0.55	1.04	0.04	0.05	0.55	1.04
South Carolina	0.00	0.00	0.00	0.00	0.00	0.00	0.05	0.08	0.00	0.00	0.05	0.08
Tennessee	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Texas	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Utah	0.00	0.00	0.00	0.00	0.02	0.02	0.17	0.33	0.02	0.02	0.17	0.33
Vermont	0.00	0.00	0.00	0.00	0.33	0.36	4.26	7.73	0.33	0.36	4.26	7.73
Virginia	0.00	0.00	0.00	0.00	0.01	0.01	0.08	0.14	0.01	0.01	0.08	0.14
West Virginia	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.00	0.01	0.01
Wisconsin	0.00	0.00	0.00	0.00	0.02	0.02	0.23	0.44	0.02	0.02	0.23	0.44
Wyoming	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.03	0.00	0.00	0.02	0.03

Note: Fuel oil is not represented in the commercial building models.

Appendix C

Maximum Potential Savings

Appendix C

Maximum Potential Savings

Currently, DOE is conducting residential and commercial field studies that are designed to determine the impact of education and training activities on reducing lost energy savings in the field. These studies can be used to calculate the additional savings that can be achieved if all potential savings from codes are realized in the field. The savings realization rate inputs described in section 2.1.5 are modified to analyze such a scenario. The realization rate is changed to 100% immediately after adoption for both residential and commercial codes. Table C.1 shows the result of this scenario. Potential cumulative site energy savings of up to 7 quads, primary energy savings of 16 quads, consumer cost savings of \$151 billion, and a CO₂ reduction of 1,028 MMT is possible for the 2010-2040 period if the realization rate is 100%. Compared to the results presented in section 3.0, additional cumulative savings from 2010-2040 are 2.83 quads (22%) of primary energy, 24.81 billion dollars (20%), and 187 MMT (22%) of avoided CO₂ emissions.

Table C.1. Summary of Energy Codes Impact with 100% Compliance

Sector	Site Energy Savings (Quads)	Primary Energy Savings (Quads)	FFC Savings (Quads)	Energy Cost Savings (2016 \$ billion)	CO ₂ Reduction (MMT)
Commercial					
Annual 2030	0.14	0.38	0.39	3.19	24.97
Annual 2040	0.18	0.46	0.48	3.62	30.50
Cumulative 2010-2030	1.70	4.50	4.73	39.62	299.22
Cumulative 2010-2040	3.34	8.71	9.15	73.98	578.71
Residential					
Annual 2030	0.15	0.29	0.31	3.24	18.96
Annual 2040	0.18	0.34	0.36	3.56	22.16
Cumulative 2010-2030	1.93	3.73	3.98	42.52	241.94
Cumulative 2010-2040	3.58	6.93	7.39	76.77	449.33
Total					
Annual 2030	0.30	0.67	0.71	6.43	43.94
Annual 2040	0.36	0.80	0.85	7.18	52.66
Cumulative 2010-2030	3.62	8.24	8.71	82.14	541.15
Cumulative 2010-2040	6.92	15.65	16.55	150.74	1028.04

Note: The following states are excluded from the analysis: AK, CA, HI, KS, MO, MS (residential only), ND, OR, SD, and WA. See section 2.1.3 for details.



Pacific Northwest
NATIONAL LABORATORY

*Proudly Operated by **Battelle** Since 1965*

902 Battelle Boulevard
P.O. Box 999
Richland, WA 99352
1-888-375-PNNL (7665)

U.S. DEPARTMENT OF
ENERGY

www.pnnl.gov